



181 US Hwy 46
Mine Hill, NJ 07803
(908) 654-8068
(800) 783-0567
Fax 908-654-8069

LEAD IN DRINKING WATER REPORT

Performed At:

Warren Township School District

Performed For:

Warren Township School District
213 Mount Horeb Rd, Warren, NJ, 07059

Prepared By:

LEW Environmental Services, LLC.
181 US Hwy 46
Mine Hill, NJ 07803

Phone (908) 654-8068
Fax (908) 654-8069
Website <http://www.LEWCorp.com>

Inspection Date: 11/01/2024
Project Number: 2539

Table of Contents

Contact Information	3
Introduction	4
Sampling Methodology	4
Drinking Water Results	5
Recommendations	6
Additional Recommendations	7

Appendices

Appendix A	Exceedances
Appendix B	Recommendations
Appendix C	All results
Appendix D	Floor Plan(S)
Appendix E	Laboratory Data

Contact Information

Education Agency

Client Contact:	Michael Pate
Client Name:	Warren Township School District
Street Address	213 Mount Horeb Rd, Warren, NJ, 07059
Phone Number:	908-753-5300

Sampler(s)

Site Assessor(s):	Erick Ulloa
Signature:	
Date:	December 10, 2024

Firm

Organization:	LEW Environmental Services, LLC.
Certification #:	NJDCA 00015 E
Street:	181 US Hwy 46
City, State & Zip:	Mine Hill, NJ 07803
Phone Number:	908-654-8068
Web Address:	http://www.lewcorp.com

Laboratory

Organization:	Environmental Hazard Services, LLC
Street:	7469 Whitepine Road
City, State & Zip:	Richmond, VA 23237
NJDEP Certification #	VA008
Phone Number:	800-347-4010

Introduction

LEW Environmental Services, LLC. was contracted by Warren Township School District to test for the presence of lead in drinking water in seven facilities in the district.

Sampling Methodology

LEW Environmental Services, LLC. followed NJAC 6A:26. Full details on sampling practices can be found in Districts Sampling Plan.

All samples were collected in 250mL wide mouth plastic containers that was prepackaged by the analytical laboratory. The sample containers may contain nitric acid, if expedited analysis is required. If not, nitric acid will be added to each sample upon arrival at the laboratory. At each sample location, the first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight hours but less than forty-eight hours. If second draw samples were collected, they were collecting following a flushing protocol outlined in the District's Sampling Plan.

Drinking Water Results

On November 1, 2024 through November 3, 2024, LEW Environmental Services, LLC. collected the following number of water samples:

Angelo L. Tomaso

- 58 first draw samples collected plus 1 QAQC blank sample
- 2 samples above the 15ppb action level
- 1 sample lost in transit and could not be analyzed.

Warren Middle School

- 52 first draw samples collected plus 1 QAQC blank sample
- 0 samples above the 15ppb action level

Mount Horeb Elementary School

- 48 first draw samples collected plus 1 QAQC blank sample
- 1 samples above the 15ppb action level

Warren Board of Education

- 2 first draw samples collected plus 1 QAQC blank sample
- 0 samples above the 15ppb action level

Central Elementary School

- 29 first draw samples collected plus 1 QAQC blank sample
- 1 sample above the 15ppb action level
- 1 sample lost in transit and could not be analyzed.

Woodland School

- 42 first draw samples collected plus 1 QAQC blank sample
- 1 sample above the 15ppb action level

Warren Twp Maintenance Bld

- 1 first draw samples collected plus 1 QAQC blank sample
- 0 samples above the 15ppb action level

The complete list of samples that exceeded the 15ppb limit can be found in Appendix A. The complete list of all sample results can be found in Appendix C. The laboratory results can be found in Appendix E.

Certain outlets could not or were not tested due to various reasons. The following table lists those locations and the reason why samples were not collected.

School	Sample Location	Reason for not testing.
Angelo L. Tomaso	Kitchen Hall right, 3-T-B-Kit Hall	Disabled

Angelo L. Tomaso	Rm 13, 21-T-SB-Rm13	Removed
Angelo L. Tomaso	Rm 6, 49-T-S-Rm 6	Removed
Warren Middle School	Hall C, M-WC-Hall C	Removed
Warren Middle School	Hall D, M-WC-Hall D	Not Functioning
Warren Middle School	Boy's Locker Rm, M-B-BLR	Not Functioning
Warren Middle School	Hall B, M-WC-Hall B	Not Functioning
Mount Horeb	Rm 14C, MH-SB-14C	Not Functioning
Mount Horeb	Rm 5C, MH-SB-5C	Removed
Central	Basement Hall, 1-C-B-BH	Not Functioning
Central	Main Hall, 10-C-WC-MH	Removed
Central	Rm 32, 14-C-B-RM32	Removed
Central	Hall RM 16, 20-C-B-RM16	Not Functioning
Central	Rm 17, 22-C-B-RM17	Removed
Central	Hall B, 23-C-W-HALL B	Not Functioning
Central	Hall B, 24-C-W-HALL B	Not Functioning
Central	Rm 20, 27-C-B-RM20	Removed
Central	Rm 21, 28-C-B-RM21	Removed
Central	Rm 22, 28-C-B-RM22	Removed
Central	Rm 23, 31-C-B-RM23	Removed
Central	Rm 25, 34-C-B-RM25	Removed
Central	Rm 30, 35-C-B-RM30	Not Functioning
Central	Rm 28, 38-C-B-RM28	Not Functioning
Woodland School	Rm 6, W-SB-RM6	Removed
Woodland School	Rm 25, W-SB-RM25	Removed

Recommendations

Those outlets where the first draw sample tested below 15ppb are not considered to be elevated and no mitigation is necessary.

For those outlets where the first draw sample exceeds 15ppb the following steps are recommended:

- 1) Immediately discontinue use of the outlets.
- 2) Conduct second draw (flush) samples on these outlets to further delineate source of contamination.

A complete list of recommendations per outlet can be found in Appendix B.

Additional Recommendations

- 1) Follow-up samples should be collected after any remediation efforts in order to determine the efficacy of the work.
- 2) Any of the inoperable/non-functioning outlets listed above that are brought back into service should be sample.
- 3) Comply with all requirements set forth in NJAC 6A:26.

Appendix A Exceedances

[illegible]

Appendix B Recommendations

Appendix C All Results

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
ANGELO L. TOMASO	11/2/24	11/14/24	1-T-S-BATH-1	BATH 1 RIGHT SINK	1.1
ANGELO L. TOMASO	11/2/24	11/14/24	2-T-S-BATH-T	BATH 2 RIGHT SINK	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	4-T-B-KIT-HALL-L	KITCHEN HALL RIGHT BUBBLER	4.84
ANGELO L. TOMASO	11/2/24	11/14/24	6-T-S-KIT	KITCHEN SINK	6.1
ANGELO L. TOMASO	11/2/24	11/14/24	7A-T-B-CAFE	CAFETERIA WATER COOLER	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	TB-T-B-CAFE	CAFETERIA BOTTLE FILLER	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	8-T-CAFE	CAFETERIA BUBBLER	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	9-T-B-GYM HALL	GYM HALL BUBBLER	1.62
ANGELO L. TOMASO	11/2/24	11/14/24	10A-T-B-GYM HALL	GYM HALL BUBBLER	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	10B-T-WC-GYM HALL	GYM HALL WATER COOLER	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	12-T-S-BATH3	BATH 3 SINK	2.44
ANGELO L. TOMASO	11/2/24	11/14/24	13-T-S-BATH4	BATH 4 SINK	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	14-T-S-RM16	RM 16 SINK	1.98
ANGELO L. TOMASO	11/2/24	11/14/24	15-T-B-RM16	RM 16 BUBBLER	1.65
ANGELO L. TOMASO	11/2/24	11/14/24	16-T-SB-RM16	RM 16 SINK/BUBBLER	9.11
ANGELO L. TOMASO	11/2/24	11/14/24	17-T-B-HALLC	HALL C BUBBLER	3.2
ANGELO L. TOMASO	11/2/24	11/14/24	18-T-SB-RM14	RM 14 SINK BUBBLER	1.94
ANGELO L. TOMASO	11/2/24	11/14/24	19-T-B-RM14	RM 14 BUBBLER	99.2
ANGELO L. TOMASO	11/2/24	11/14/24	20-T-S-RM14	RM 14 SINK	11.2
ANGELO L. TOMASO	11/2/24	11/14/24	22-T-S-RM13	RM 13 SINK	1.6
ANGELO L. TOMASO	11/2/24	11/14/24	23-T-SB-K1	RM K1 SINK/BUBBLER	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	24-T-SB-K2	RM K2 SINK/BUBBLER	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	25-T-B-HALLC	HALL C BUBBLER	2.68
ANGELO L. TOMASO	11/2/24	11/14/24	26-T-SB-RM20	RM 18 SINK/BUBBLER	5.04
ANGELO L. TOMASO	11/2/24	11/14/24	27-T-SB-RM20	RM 20 SINK/BUBBLER	33.3
ANGELO L. TOMASO	11/2/24	11/14/24	28-T-SB-RM22	RM 22 SINK/BUBBLER	10.3
ANGELO L. TOMASO	11/2/24	11/14/24	29-T-S-RM23	RM 23 SINK	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	30-T-SB-RM24	RM 24 SINK/BUBBLER	1.32
ANGELO L. TOMASO	11/2/24	11/14/24	31-T-SB-RM30	RM 30 SINK/BUBBLER	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	32-T-SB-RM27	RM 27 SINK/BUBBLER	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	33-T-SB-RM29	RM 29 SINK/BUBBLER	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	34-T-SB-RM26	RM 26 SINK/BUBBLER	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	35-T-SB-RM28	RM 28 SINK/BUBBLER	1.53
ANGELO L. TOMASO	11/2/24	11/14/24	36-T-SB-RM33A	RM 33A SINK/BUBBLER	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	37-T-S-BATH5	BATH 5 SINK	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	38-T-S-BATH6	BATH 6 SINK	3.88
ANGELO L. TOMASO	11/2/24	11/14/24	39-T-SB-RM31	RM 31 SINK/BUBBLER	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	40-T-S-RM1	RM 1 LEFT SINK	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	41-T-S-NURSE	NURSE SINK	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	42-T-S-NURSE	NURSE SINK	1.29
ANGELO L. TOMASO	11/2/24	11/14/24	43-T-S-STAFF	STAFF SINK	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	44-T-S-LIB	LIBRARY SINK	3.28
ANGELO L. TOMASO	11/2/24	11/14/24	45-T-S-BATH7	BATH 7 SINK	2.85
ANGELO L. TOMASO	11/2/24	11/14/24	46A-T-B-HALLA	HALL A BOTTLE FILLER	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	46B-T-WC-HALLA	HALL A WATER COOLER	<1.00
ANGELO L. TOMASO	11/2/24	11/14/24	48-T-S-BATH8	BATH 8 SINK	2.68
ANGELO L. TOMASO	11/2/24	11/14/24	50-T-B-RM7	RM 7 BUBBLER	14.3
ANGELO L. TOMASO	11/2/24	11/14/24	51-T-SB-RM9	RM 9 SINK/BUBBLER	1.17
ANGELO L. TOMASO	11/2/24	11/14/24	52-T-SB-RM11	RM 11 SINK/BUBBLER	1.7
ANGELO L. TOMASO	11/2/24	11/14/24	53-T-SB-RM10	RM 10 SINK/BUBBLER	<1.00

[illegible]

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-WC-HALL C	HALL C WATER COOLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-BF-HALL C	HALL C BOTTLE FILLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	3-M-S-ART	ART RM SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	4-M-S-ART	ART RM SINK	1.21
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-RM-40	RM 40 SINK	9.79
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-RM-42	RM 42 SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-STAFF	STAFF SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-BF-HALL D	HALL D BOTTLE FILLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-BATH 1	BATH 1 SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-BATH 2	BATH 2 SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-RM 52	RM 52 SINK	1.34
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-BR	BOILER RM SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-RM 33	RM 33 SINK	1.47
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-WC-HALL C	HALL C WATER COOLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-BATH 3	BATH 3 SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-BATH 4	BATH 4 SINK	1.48
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-BF-CAF	IN APR BOTTLE FILLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-WC-CAF	IN APR WATER COOLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-BF-RM 35	RM 35 BOTTLE FILLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-WC-RM 35	RM 35 WATER COOLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-BLR	BOYS LOCKER RM SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-RM 32	RM 32 SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S1-RM 31	RM 31 SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S2-RM 31	RM 31 SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S3-RM 31	RM 31 SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S4-RM 31	RM 31 SINK	5.5
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-BF-LH	LIBRARY HALL BOTTLE FILLER	<1.00

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-WC-LH	LIBRARY HALL WATER COOLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-RM 25	RM 25 SINK	2.39
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-SP	SCIENCE PREP SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-RM 21	RM 21 SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-BF-LH	BY RM 21 BOTTLE FILLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-WC-LH	BY RM 21 WATER COOLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-BATH 5	BOYS BATHROOM SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-RM 17	RM 17 SINK	4.8
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-BF-HALL A	BY RM 12 BOTTLE FILLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-WC-HALL A	BY RM 12 WATER COOLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-BATH 6	BATH 6 SINK	1.23
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-RM 7	RM 7 SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-IT-RM	IT RM SINK	9.75
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-BF-HALL A	BY 6TH GRADE STAFF ROOM BOTTLE FILLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-WC-HALL A	BY 6TH GRADE STAFF ROOM WATER COOLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-STAFF 2	6TH GRADE STAFF RM SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-OFFICE	MAIN OFFICE SINK	1.21
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-WC-HALL B	HALL B WATER COOLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-BF-HALL B	HALL B BOTTLE FILLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-BATH 7	BATH 7 SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-BATH 8	BATH 8 SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S1 NURSE	NURSE SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S2-NURSE	NURSE SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-S-GLR	GIRLS LOCKER RM SINK	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-BF-HALL C	HALL C BOTTLE FILLER	<1.00
WARREN MIDDLE SCHOOL	11/7/24	11/12/24	M-SR	SUNROOM	<1.00

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
MOUNT HOREB	11/2/24	11/13/24	1MH-S-OFFICE	MAIN OFFICE SINK	<1.00
MOUNT HOREB	11/2/24	11/13/24	2MH-S-BATH1	BOYS BATHROOM SINK	<1.00
MOUNT HOREB	11/2/24	11/13/24	3MH-S-BATH2	GIRLS BATHROOM SINK	<1.00
MOUNT HOREB	11/2/24	11/13/24	4MH-BF-HALLA	HALL APR BOTTLE FILLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	5MH-WC-HALLA	HALL APR WATER COOLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	6MH-WC-HALLA	HALL APR WATER COOLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	7MH-SB-1A	RM 1A BUBBLER	85.4
MOUNT HOREB	11/2/24	11/13/24	8MH-SB-2A	RM 2A BUBBLER	5.34
MOUNT HOREB	11/2/24	11/13/24	9MH-S-KIT	KITCHEN SINK	1.49
MOUNT HOREB	11/2/24	11/13/24	10MH-S-STAFF	FACULTY LOUNGE SINK	<1.00
MOUNT HOREB	11/2/24	11/13/24	11MH-SB-3A	RM 3A BUBBLER	3.03
MOUNT HOREB	11/2/24	11/13/24	12MH-SB-4A	RM 4A BUBBLER	13.8
MOUNT HOREB	11/2/24	11/13/24	13MH-SB-5A	RM 5A BUBBLER	4.67
MOUNT HOREB	11/2/24	11/13/24	14MH-SB-10A	RM 10A BUBBLER	5.59
MOUNT HOREB	11/2/24	11/13/24	15MH-SB-6A	RM 6A BUBBLER	9.83
MOUNT HOREB	11/2/24	11/13/24	16MH-SB-9A	RM 9A BUBBLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	17MH-SB-8A	RM 8A BUBBLER	1.05
MOUNT HOREB	11/2/24	11/13/24	18MH-SB-7A	RM 7A BUBBLER	1.51
MOUNT HOREB	11/2/24	11/13/24	19MH-S-NURSE	NURSE SINK	<1.00
MOUNT HOREB	11/2/24	11/13/24	20MH-SB-2B	RM 2B BUBBLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	21MH-SB-16B	RM 16B BUBBLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	22MH-SB-3B	RM 3B BUBBLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	23MH-SB-13B	RM 13, BUBBLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	24MH-BF-HALLB	HALL B BOTTLE FILLER	1.62
MOUNT HOREB	11/2/24	11/13/24	25MH-WC-HALLB	HALL B WATER COOLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	26MH-S-BATH3	BOYS BATHROOM SINK	<1.00
MOUNT HOREB	11/2/24	11/13/24	27MH-S-BATH4	GIRLS BATHROOM SINK	<1.00
MOUNT HOREB	11/2/24	11/13/24	28MH-SB-4B	RM 4B BUBBLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	29MH-SB-12B	RM 12B BUBBLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	30MH-SB-6B	RM 6B BUBBLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	31MH-SB-7B	RM 7B BUBBLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	32MH-SB-10B	RM 10B BUBBLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	33MH-SB-8B	RM 8B BUBBLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	34MH-SB-9B	RM 9B BUBBLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	35MH-S-BATH5	BOYS BATH SINK	<1.00
MOUNT HOREB	11/2/24	11/13/24	36MH-S-BATH6	GIRLS BATH SINK	<1.00
MOUNT HOREB	11/2/24	11/13/24	37MH-BF-HALLC	HALL C BOTTLE FILLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	38MH-W-HALLC	HALL C WATER COOLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	39MH-WC-HALLC	HALL C WATER COOLER	<1.00
MOUNT HOREB	11/2/24	11/13/24	40MH-S-LB	LIBRARY SINK	2.91
MOUNT HOREB	11/2/24	11/13/24	42MH-SB-13C	RM 13C BUBBLER	10.3
MOUNT HOREB	11/2/24	11/13/24	43MH-SB-12C	RM 12C BUBBLER	5.17
MOUNT HOREB	11/2/24	11/13/24	44MH-SB-11C	RM 11C BUBBLER	3.33
MOUNT HOREB	11/2/24	11/13/24	46MH-SB-6C	RM 6C BUBBLER	5.93
MOUNT HOREB	11/2/24	11/13/24	47MH-SB-10C	RM 10C BUBBLER	7.41
MOUNT HOREB	11/2/24	11/13/24	48MH-S-8C	RM 8C SINK	<1.00
MOUNT HOREB	11/2/24	11/13/24	49MH-S-BATH7	BATHROOM SINK	<1.00
MOUNT HOREB	11/2/24	11/13/24	50MH-S-9C	RM 9C SINK	1.02
MOUNT HOREB	11/2/24	11/13/24	51MH-SR	SUNROOM	<1.00


[illegible]

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
WOODLAND	11/3/24	11/12/24	W-SB-RM2	RM 2 SINK/ BUBBLER	<1.00
WOODLAND	11/3/24	11/12/24	W-SB-RM3	RM 3 SINK/BUBBLER	4.06
WOODLAND	11/3/24	11/12/24	W-SB-RM5	RM 5 SINK/BUBBLER	<1.00
WOODLAND	11/3/24	11/12/24	W-SB-RM4	RM 4 SINK/BUBBLER	<1.00
WOODLAND	11/3/24	11/12/24	W-S-BATH1	BOYS BATH BY STAFF SINK	2.09
WOODLAND	11/3/24	11/12/24	W-S-STAFF	FACULTY RM SINK/BUBBLER	15.3
WOODLAND	11/3/24	11/12/24	W-BF-HALLA	BOTTLE FILLER BY FACULTY BOTTLE FILLER	<1.00
WOODLAND	11/3/24	11/12/24	W-WC-HALLA	WATER COOLER BY FACULTY WATER COOLER	<1.00
WOODLAND	11/3/24	11/12/24	W-S-BATH2	GIRLS BATH BY STAFF RM SINK	3.01
WOODLAND	11/3/24	11/12/24	W-S-BATH3	BATH BY RM 7 SINK	2.58
WOODLAND	11/3/24	11/12/24	W-SB-RM7	RM 7 BUBBLER	8.72
WOODLAND	11/3/24	11/12/24	W-SB-RM10	RM 10 BUBBLER	<1.00
WOODLAND	11/3/24	11/12/24	W-SB1-RM9	RM 9 BUBBLER	<1.00
WOODLAND	11/3/24	11/12/24	W-SB2-RM9	IN BETWEEN RM 9 BUBBLER	3.43
WOODLAND	11/3/24	11/12/24	W-S1-KITCHEN	KITCHEN SINK 1	3.64
WOODLAND	11/3/24	11/12/24	W-S2-KITCHEN	KITCHEN SINK 2	<1.00
WOODLAND	11/3/24	11/12/24	W-BF-CAF	BOTTLE FILLER IN APR BOTTLE FILLER	<1.00
WOODLAND	11/3/24	11/12/24	W-WC-CAF	WATER COOLER IN APR WATER COOLER	<1.00
WOODLAND	11/3/24	11/12/24	W-S1-NURSE	NURSE SINK 1	<1.00
WOODLAND	11/3/24	11/12/24	W-S2-NURSE	NURSE SINK 2	3.38
WOODLAND	11/3/24	11/12/24	W-SB-RM12	RM 12 SINK/BUBBLER	10
WOODLAND	11/3/24	11/12/24	W-S-BATH4	GIRLS BATH LOWER WING SINK	1.37
WOODLAND	11/3/24	11/12/24	W-S-BATH5	BOYS BATH LOWER WING SINK	<1.00
WOODLAND	11/3/24	11/12/24	W-SB-RM23	RM 23 BUBBLER	4.53
WOODLAND	11/3/24	11/12/24	W-SB-RM22	RM 22 BUBBLER	<1.00
WOODLAND	11/3/24	11/12/24	W-SB-RM24	RM 24 BUBBLER	1.8
WOODLAND	11/3/24	11/12/24	W-SB-RM27	RM 27 BUBBLER	1.29
WOODLAND	11/3/24	11/12/24	W-BF-HALL B	BY RM 27 BOTTLE FILLER	<1.00
WOODLAND	11/3/24	11/12/24	W-WC-HALL B	BY RM 27 WATER COOLER	<1.00
WOODLAND	11/3/24	11/12/24	W-SB-RM26	RM 26 BUBBLER	1.26
WOODLAND	11/3/24	11/12/24	W-SB-RM29	RM 29 BUBBLER	1.6
WOODLAND	11/3/24	11/12/24	W-SB-RM28	RM 28 BUBBLER	<1.00
WOODLAND	11/3/24	11/12/24	W-SB-RM30	RM 30 BUBBLER	<1.00
WOODLAND	11/3/24	11/12/24	W-SB-RM32	RM 32 BUBBLER	<1.00
WOODLAND	11/3/24	11/12/24	W-S1-RM34	RM 34 SINK 1	2.48
WOODLAND	11/3/24	11/12/24	W-S2-RM34	RM 34 SINK 2	1.88
WOODLAND	11/3/24	11/12/24	W-S-BATH6	BOYS BATH BY LIBRARY SINK	3.84
WOODLAND	11/3/24	11/12/24	W-S-BATH7	GIRLS BATH BY LIBRARY SINK	1.21
WOODLAND	11/3/24	11/12/24	W-S-LIB	LIBRARY SINK	2.61
WOODLAND	11/3/24	11/12/24	W-BF-HALLC	BY GYM BOTTLE FILLER	<1.00
WOODLAND	11/3/24	11/12/24	W-WC-HALLC	BY GYM WATER COOLER	<1.00
WOODLAND	11/3/24	11/12/24	2-S-BATH8	BATH 8 SINK	<1.00
WOODLAND	11/3/24	11/12/24	W-SR	SUNROOM	3.91

[illegible]

Appendix D Floor Plan(s)

A.L. Tomaso School




Floor Plan - A L Tomaso school

← street →

Ami

Central School

● = Budget
 ● = Character Features
 ● = Furniture
 ● = Style




Floor Plan - Central School - main levels

street

Central School

basement




Floor Plan - Central School- basement

Middle School

B




43




Floor plan - Middle School

14. Horeb School



R - street - S

Floor Plan - Mt Horeb School



Warren Township School Board - Maintenance Building
2/22/91 - Stinking Creek & Mt. Avenue no scale

8,766 58. Ft.


ORIGINAL CONSTRUCTION DATE UNKNOWN

Woodland School

B = bubbler

S = sink

SB = sink/bubbler




42



Street →

Floor plan - Woodland School



Flood Plan - Warren Twp BOE

Appendix E Laboratory Data



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 24-11-01510

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Received Date: 11/08/2024
Reported Date: 11/15/2024
Sampled By: Erick Ulloa
Tech Certification #:

Project/Test Address: 2539; 46 Washington Valley Rd; Warren, NJ

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-01510-001	1-T-S-BATH-1	11/02/2024	BATH 1 RIGHT SINK	1.10	11/14/2024	
24-11-01510-002	2-T-S-BATH-T	11/02/2024	BATH 2 RIGHT SINK	<1.00	11/14/2024	
24-11-01510-003	4-T-B-KIT-HALL-L	11/02/2024	KITCHEN HALL RIGHT BUBBLER	4.84	11/14/2024	
24-11-01510-004	6-T-S-KIT	11/02/2024	KITCHEN SINK	6.10	11/14/2024	
24-11-01510-005	7A-T-B-CAFE	11/02/2024	CAFETERIA WATER COOLER	<1.00	11/14/2024	
24-11-01510-006	TB-T-B-CAFE	11/02/2024	CAFETERIA BOTTLE FILLER	<1.00	11/14/2024	
24-11-01510-007	8-T-CAFE	11/02/2024	CAFETERIA BUBBLER	<1.00	11/14/2024	
24-11-01510-008	9-T-B-GYM HALL	11/02/2024	GYM HALL BUBBLER	1.62	11/14/2024	
24-11-01510-009	10A-T-B-GYM HALL	11/02/2024	GYM HALL BUBBLER	<1.00	11/14/2024	
24-11-01510-010	10B-T-WC-GYM HALL	11/02/2024	GYM HALL WATER COOLER	<1.00	11/14/2024	
24-11-01510-011	12-T-S-BATH3	11/02/2024	BATH 3 SINK	2.44	11/14/2024	
24-11-01510-012	13-T-S-BATH4	11/02/2024	BATH 4 SINK	<1.00	11/14/2024	
24-11-01510-013	14-T-S-RM16	11/02/2024	RM 16 SINK	1.98	11/14/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 24-11-01510

Project/Test Address: 2539; 46 Washington Valley Rd; Warren, NJ

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-01510-014	15-T-B-RM16	11/02/2024	RM 16 BUBBLER	1.65	11/14/2024	
24-11-01510-015	16-T-SB-RM16	11/02/2024	RM 16 SINK/BUBBLER	9.11	11/14/2024	
24-11-01510-016	17-T-B-HALLC	11/02/2024	HALL C BUBBLER	3.20	11/14/2024	
24-11-01510-017	18-T-SB-RM14	11/02/2024	RM 14 SINK BUBBLER	1.94	11/14/2024	
24-11-01510-018	19-T-B-RM14	11/02/2024	RM 14 BUBBLER	99.2	11/14/2024	
24-11-01510-019	20-T-S-RM14	11/02/2024	RM 14 SINK	11.2	11/14/2024	
24-11-01510-020	22-T-S-RM13	11/02/2024	RM 13 SINK	1.60	11/14/2024	
24-11-01510-021	23-T-SB-K1	11/02/2024	RM K1 SINK/BUBBLER	<1.00	11/14/2024	
24-11-01510-022	24-T-SB-K2	11/02/2024	RM K2 SINK/BUBBLER	<1.00	11/14/2024	
24-11-01510-023	25-T-B-HALLC	11/02/2024	HALL C BUBBLER	2.68	11/14/2024	
24-11-01510-024	26-T-SB-RM20	11/02/2024	RM 18 SINK/BUBBLER	5.04	11/14/2024	
24-11-01510-025	27-T-SB-RM20	11/02/2024	RM 20 SINK/BUBBLER	33.3	11/14/2024	
24-11-01510-026	28-T-SB-RM22	11/02/2024	RM 22 SINK/BUBBLER	10.3	11/14/2024	
24-11-01510-027	29-T-S-RM23	11/02/2024	RM 23 SINK	<1.00	11/14/2024	
24-11-01510-028	30-T-SB-RM24	11/02/2024	RM 24 SINK/BUBBLER	1.32	11/14/2024	
24-11-01510-029	31-T-SB-RM30	11/02/2024	RM 30 SINK/BUBBLER	<1.00	11/14/2024	
24-11-01510-030	32-T-SB-RM27	11/02/2024	RM 27 SINK/BUBBLER	<1.00	11/14/2024	
24-11-01510-031	33-T-SB-RM29	11/02/2024	RM 29 SINK/BUBBLER	<1.00	11/14/2024	
24-11-01510-032	34-T-SB-RM26	11/02/2024	RM 26 SINK/BUBBLER	<1.00	11/14/2024	
24-11-01510-033	35-T-SB-RM28	11/02/2024	RM 28 SINK/BUBBLER	1.53	11/14/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 24-11-01510

Project/Test Address: 2539; 46 Washington Valley Rd; Warren, NJ

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-01510-034	36-T-SB-RM33A	11/02/2024	RM 33A SINK/BUBBLER	<1.00	11/14/2024	
24-11-01510-035	37-T-S-BATH5	11/02/2024	BATH 5 SINK	<1.00	11/14/2024	
24-11-01510-036	38-T-S-BATH6	11/02/2024	BATH 6 SINK	3.88	11/14/2024	
24-11-01510-037	39-T-SB-RM31	11/02/2024	RM 31 SINK/BUBBLER	<1.00	11/14/2024	
24-11-01510-038	40-T-S-RM1	11/02/2024	RM 1 LEFT SINK	<1.00	11/14/2024	
24-11-01510-039	41-T-S-NURSE	11/02/2024	NURSE SINK	<1.00	11/14/2024	
24-11-01510-040	42-T-S-NURSE	11/02/2024	NURSE SINK	1.29	11/14/2024	
24-11-01510-041	43-T-S-STAFF	11/02/2024	STAFF SINK	<1.00	11/14/2024	
24-11-01510-042	44-T-S-LIB	11/02/2024	LIBRARY SINK	3.28	11/14/2024	
24-11-01510-043	45-T-S-BATH7	11/02/2024	BATH 7 SINK	2.85	11/14/2024	
24-11-01510-044	46A-T-B-HALLA	11/02/2024	HALL A BOTTLE FILLER	<1.00	11/14/2024	
24-11-01510-045	46B-T-WC-HALLA	11/02/2024	HALL A WATER COOLER	<1.00	11/14/2024	
24-11-01510-046	48-T-S-BATH8	11/02/2024	BATH 8 SINK	2.68	11/14/2024	
24-11-01510-047	50-T-B-RM7	11/02/2024	RM 7 BUBBLER	14.3	11/14/2024	
24-11-01510-048	51-T-SB-RM9	11/02/2024	RM 9 SINK/BUBBLER	1.17	11/14/2024	
24-11-01510-049	52-T-SB-RM11	11/02/2024	RM 11 SINK/BUBBLER	1.70	11/14/2024	
24-11-01510-050	53-T-SB-RM10	11/02/2024	RM 10 SINK/BUBBLER	<1.00	11/14/2024	
24-11-01510-051	54-T-SB-RM12	11/02/2024	RM 12 SINK/BUBBLER	<1.00	11/14/2024	
24-11-01510-052	56-T-SB-RMA	11/02/2024	RM A SINK/BUBBLER	5.34	11/14/2024	
24-11-01510-053	57-WC-COPY	11/02/2024	COPY ROOM WATER COOLER	<1.00	11/14/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 24-11-01510

Project/Test Address: 2539; 46 Washington Valley Rd; Warren, NJ

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-01510-054	58-T-B-COPY	11/02/2024	COPY ROOM BOTTLE FILLER	<1.00	11/14/2024	
24-11-01510-055	59-T-B-RM25	11/02/2024	RM 25 BUBBLER	2.46	11/14/2024	
24-11-01510-056	60-T-B-RMC	11/02/2024	RM C BUBBLER	1.50	11/14/2024	
24-11-01510-057	61-T-SB-RMB	11/02/2024	RM B BUBBLER	<1.00	11/14/2024	
24-11-01510-058	62-T-SB-RM8	11/02/2024	RM 8 BUBBLER	3.92	11/14/2024	
24-11-01510-059	63-T-SR	11/02/2024	SUNROOM	6.83	11/14/2024	

Method: EPA 200.8

Analyst: Nicole Holloway

Accreditation #: NJ VA008

Reviewed By Authorized Signatory:



Candace Mason

QA Chemist

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



ENVIRONMENTAL HAZARDS SERVICES, LLC

WaterSmart® Lead Chain-of-Custody Form

Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907
www.leadlab.com

24-11-01510



Due Date:

11/15/2024

(Friday)

AE

Client Name: LEW CORP Account #: 201327

Address: 181 US HIGHWAY 46

City/State/Zip: MINE HILL, NJ 07803

Phone: 908-654-8068

Email Address: labresults@lewcorp.com

Project Name/ Number: 2539

Collection Address: 46 WASHINGTON VALLEY RD City/State/Zip: WARREN, NJ
(Required) (Required)

Approx. Age Of Property: _____ Collected By: ERICK ULLOA

Water Source: (Check One) Public ☒ or Well _____

Well Tag # (if applicable): _____

Turn-Around Time ☒ 5 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
1	1-T-S-BATH 1	BATH 1 RIGHT, SINK	11-02-2024	AM / PM	X	
2	2-T-S-BATH 2	BATH 2 RIGHT, SINK		AM / PM	X	
3	4-T-B-KIT HALL-L	KITCEHN HALL RIGHT, BUBBLER		AM / PM	X	
4	5-T-S-KIT	KITCHEN, SINK	*sample not received by 11/8/24		X	
5	6-T-S-KIT	KITCHEN, SINK		AM / PM	X	
6	7A-T-B-CAFE	CAFETERIA, WATER COOLER		AM / PM	X	
7	7B-T-B-CAFE	CAFETERIA, BOTTLE FILLER		AM / PM	X	
8	8-T-CAFE	CAFETERIA, BUBBLER		AM / PM	X	
9	9-T-B-GYM HALL	GYM HALL, BUBBLER		AM / PM	X	
10	10A-T-B-GYM HALL	GYM HALL, BUBBLER		AM / PM	X	
11	10B-T-WC-GYM HALL	GYM HALL, WATER COOLER		AM / PM	X	
12	12-T-S-BATH 3	BATH 3, SINK		AM / PM	X	
13	13-T-S-BATH 4	BATH 4, SINK		AM / PM	X	
14	14-T-S-RM 16	RM 16, SINK		AM / PM	X	
15	15-T-B-RM 16	RM 16, BUBBLER		AM / PM	X	

Released by: ERICK ULLOA

Signature: _____

Date/Time: 11-02-2024

Received by: CHRISTMAS


Signature: _____

Date/Time: 11/8/24 1240PM

Project Name: **2539**

Lab I.D. #: **01510**


No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
51	16-T-SB-RM 16	RM 16, SINK/BUBBLER	11-02-2024	AM / PM	X	
52	17-T-B-HALL C	HALL C, BUBBLER		AM / PM	X	
53	18-T-SB-RM 14	RM 14, SINK.BUBBLER		AM / PM	X	
54	19-T-B-RM 14	RM 14, BUBBLER		AM / PM	X	
55	20-T-S-RM 14	RM 14, SINK		AM / PM	X	
56	22-T-S-RM 13	RM 13, SINK		AM / PM	X	
57	23-T-SB-K1	RM K1, SINK/BUBBLER		AM / PM	X	
58	24-T-SB-K2	RM K2, SINK/BUBBLER		AM / PM	X	
59	25-T-B-HALL C	HALL C, BUBBLER		AM / PM	X	
60	26-T-SB-RM 18	RM 18, SINK/BUBBLER		AM / PM	X	
61	27-T-SB-RM 20	RM 20, SINK/BUBBLER		AM / PM	X	
62	28-T-SB-RM 22	RM 22, SINK/BUBBLER		AM / PM	X	
63	29-T-S-RM 23	RM 23, SINK		AM / PM	X	
64	30-T-SB-RM 24	RM 24, SINK/BUBBLER		AM / PM	X	
65	31-T-SB-RM 30	RM 30, SINK/BUBBLER		AM / PM	X	
66	32-T-SB-RM 27	RM 27, SINK/BUBBLER		AM / PM	X	
67	33-T-SB-RM 29	RM 29, SINK/BUBBLER		AM / PM	X	
68	34-T-SB-RM 26	RM 26, SINK/BUBBLER		AM / PM	X	
69	35-T-SB-RM 28	RM 28, SINK/BUBBLER		AM / PM	X	
70	36-T-SB-RM 33A	RM 33A, SINK/BUBBLER		AM / PM	X	
71	37-T-S-BATH 5	BATH 5, SINK		AM / PM	X	
72	38-T-S BATH 6	BATH 6, SINK		AM / PM	X	
73	39-T-SB-RM 31	RM 31, SINK/BUBBLER		AM / PM	X	
74	40-T-S-RM 1	RM 1 LEFT, SINK		AM / PM	X	
75	41-T-S-NURSE	NURSE, SINK		AM / PM	X	
76	42-T-S-NURSE	NURSE, SINK		AM / PM	X	
77	43-T-S-STAFF	STAFF, SINK		AM / PM	x	
78	44-T-S-LIB	LIBRARY, SINK		AM / PM	X	
79	45-T-S-BATH 7	BATH 7, SINK		AM / PM	X	
80	46A-T-B-HALL A	HALL A, BOTTLE FILLER		AM / PM	X	
81	46B-T-WC-HALL A	HALL A, WATER COOLER		AM / PM	X	
82	48-T-S-BATH 8	BATH 8, SINK		AM / PM	X	
83	50-T-B-RM 7	RM 7, BUBBLER		AM / PM	X	
84	51-T-SB-RM 9	RM 9, SINK/BUBBLER		AM / PM	X	
85	52-T-SB-RM 11	RM 11, SINK/BUBBLER		AM / PM	X	

Released by: ERICK ULLOA	Signature: 	Date/Time: 11-02-2024
Received by: 	Signature: 	Date/Time: 11/8/24 1240pm

Project Name: **2539**

Lab I.D. #: **01510**

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
16	53-T-SB-RM 10	RM 10, SINK/BUBBLER	11-02-2024	AM / PM	X	
17	54-T-SB-RM 12	RM 12, SINK/BUBBLER		AM / PM	X	
18				AM / PM	X	
19	56-T-SB-RM A	RM A, SINK/BUBBLER		AM / PM	X	
20	57-WC-COPY	COPY ROOM, WATER COOLER		AM / PM	X	
21	58-T-B-COPY	COPY ROOM, BOTTLE FILLER		AM / PM	X	
22	59-T-B-RM 25	RM 25, BUBBLER		AM / PM	X	
23	60-T-B-RM C	RM C, BUBBLER		AM / PM	X	
24	61-T-SB-RM B	RM B, BUBBLER		AM / PM	X	
25	62-T-SB-RM 8	RM 8, BUBBLER		AM / PM	X	
26	63-T-SR	SUNROOM		AM / PM	X	
27				AM / PM	X	
28				AM / PM	X	
29				AM / PM	X	
30				AM / PM	X	
31				AM / PM	X	
32				AM / PM	X	
33				AM / PM	X	
34				AM / PM	X	
35				AM / PM	X	
36				AM / PM	X	
37				AM / PM	X	
38				AM / PM	X	
39				AM / PM	X	
40				AM / PM	X	
41				AM / PM	X	
42				AM / PM		
43				AM / PM		
44				AM / PM		
45				AM / PM		
46				AM / PM		
47				AM / PM		
48				AM / PM		
49				AM / PM		
50				AM / PM		

Released by: ERICK ULLOA	Signature: 	Date/Time: 11-02-2024
Received by: 	Signature: 	Date/Time: 11/9/24 1240 PM



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 24-11-00958

Received Date: 11/06/2024
Reported Date: 11/13/2024
Sampled By: Erick Ulloa
Tech Certification #:

Project/Test Address: 2539; 100 Old Stirling Rd; Warren, NJ 07059

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-00958-001	M-WC-HALL C	11/07/2024	HALL C WATER COOLER	<1.00	11/12/2024	
24-11-00958-002	M-BF-HALL C	11/07/2024	HALL C BOTTLE FILLER	<1.00	11/12/2024	
24-11-00958-003	3-M-S-ART	11/07/2024	ART RM SINK	<1.00	11/12/2024	
24-11-00958-004	4-M-S-ART	11/07/2024	ART RM SINK	1.21	11/12/2024	
24-11-00958-005	M-S-RM-40	11/07/2024	RM 40 SINK	9.79	11/12/2024	
24-11-00958-006	M-S-RM-42	11/07/2024	RM 42 SINK	<1.00	11/12/2024	
24-11-00958-007	M-S-STAFF	11/07/2024	STAFF SINK	<1.00	11/12/2024	
24-11-00958-008	M-BF-HALL D	11/07/2024	HALL D BOTTLE FILLER	<1.00	11/12/2024	
24-11-00958-009	M-S-BATH 1	11/07/2024	BATH 1 SINK	<1.00	11/12/2024	
24-11-00958-010	M-S-BATH 2	11/07/2024	BATH 2 SINK	<1.00	11/12/2024	
24-11-00958-011	M-S-RM 52	11/07/2024	RM 52 SINK	1.34	11/12/2024	
24-11-00958-012	M-S-BR	11/07/2024	BOILER RM SINK	<1.00	11/12/2024	
24-11-00958-013	M-S-RM 33	11/07/2024	RM 33 SINK	1.47	11/12/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 24-11-00958

Project/Test Address: 2539; 100 Old Stirling Rd; Warren, NJ 07059

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-00958-014	M-WC-HALL C	11/07/2024	HALL C WATER COOLER	<1.00	11/12/2024	
24-11-00958-015	M-S-BATH 3	11/07/2024	BATH 3 SINK	<1.00	11/12/2024	
24-11-00958-016	M-S-BATH 4	11/07/2024	BATH 4 SINK	1.48	11/12/2024	
24-11-00958-017	M-BF-CAF	11/07/2024	IN APR BOTTLE FILLER	<1.00	11/12/2024	
24-11-00958-018	M-WC-CAF	11/07/2024	IN APR WATER COOLER	<1.00	11/12/2024	
24-11-00958-019	M-BF-RM 35	11/07/2024	RM 35 BOTTLE FILLER	<1.00	11/12/2024	
24-11-00958-020	M-WC-RM 35	11/07/2024	RM 35 WATER COOLER	<1.00	11/12/2024	
24-11-00958-021	M-S-BLR	11/07/2024	BOYS LOCKER RM SINK	<1.00	11/12/2024	
24-11-00958-022	M-S-RM 32	11/07/2024	RM 32 SINK	<1.00	11/12/2024	
24-11-00958-023	M-S1-RM 31	11/07/2024	RM 31 SINK	<1.00	11/12/2024	
24-11-00958-024	M-S2-RM 31	11/07/2024	RM 31 SINK	<1.00	11/12/2024	
24-11-00958-025	M-S3-RM 31	11/07/2024	RM 31 SINK	<1.00	11/12/2024	
24-11-00958-026	M-S4-RM 31	11/07/2024	RM 31 SINK	5.50	11/12/2024	
24-11-00958-027	M-BF-LH	11/07/2024	LIBRARY HALL BOTTLE FILLER	<1.00	11/12/2024	
24-11-00958-028	M-WC-LH	11/07/2024	LIBRARY HALL WATER COOLER	<1.00	11/12/2024	
24-11-00958-029	M-S-RM 25	11/07/2024	RM 25 SINK	2.39	11/12/2024	
24-11-00958-030	M-S-SP	11/07/2024	SCIENCE PREP SINK	<1.00	11/12/2024	
24-11-00958-031	M-S-RM 21	11/07/2024	RM 21 SINK	<1.00	11/12/2024	
24-11-00958-032	M-BF-LH	11/07/2024	BY RM 21 BOTTLE FILLER	<1.00	11/12/2024	
24-11-00958-033	M-WC-LH	11/07/2024	BY RM 21 WATER COOLER	<1.00	11/12/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 24-11-00958

Project/Test Address: 2539; 100 Old Stirling Rd; Warren, NJ 07059

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-00958-034	M-S-BATH 5	11/07/2024	BOYS BATHROOM SINK	<1.00	11/12/2024	
24-11-00958-035	M-S-RM 17	11/07/2024	RM 17 SINK	4.80	11/12/2024	
24-11-00958-036	M-BF-HALL A	11/07/2024	BY RM 12 BOTTLE FILLER	<1.00	11/12/2024	
24-11-00958-037	M-WC-HALL A	11/07/2024	BY RM 12 WATER COOLER	<1.00	11/12/2024	
24-11-00958-038	M-S-BATH 6	11/07/2024	BATH 6 SINK	1.23	11/12/2024	
24-11-00958-039	M-S-RM 7	11/07/2024	RM 7 SINK	<1.00	11/12/2024	
24-11-00958-040	M-S-IT-RM	11/07/2024	IT RM SINK	9.75	11/12/2024	
24-11-00958-041	M-BF-HALL A	11/07/2024	BY 6TH GRADE STAFF ROOM BOTTLE FILLER	<1.00	11/12/2024	
24-11-00958-042	M-WC-HALL A	11/07/2024	BY 6TH GRADE STAFF ROOM WATER COOLER	<1.00	11/12/2024	
24-11-00958-043	M-S-STAFF 2	11/07/2024	6TH GRADE STAFF RM SINK	<1.00	11/12/2024	
24-11-00958-044	M-S-OFFICE	11/07/2024	MAIN OFFCIE SINK	1.21	11/12/2024	
24-11-00958-045	M-WC-HALL B	11/07/2024	HALL B WATER COOLER	<1.00	11/12/2024	
24-11-00958-046	M-BF-HALL B	11/07/2024	HALL B BOTTLE FILLER	<1.00	11/12/2024	
24-11-00958-047	M-S-BATH 7	11/07/2024	BATH 7 SINK	<1.00	11/12/2024	
24-11-00958-048	M-S-BATH 8	11/07/2024	BATH 8 SINK	<1.00	11/12/2024	
24-11-00958-049	M-S1 NURSE	11/07/2024	NURSE SINK	<1.00	11/12/2024	
24-11-00958-050	M-S2-NURSE	11/07/2024	NURSE SINK	<1.00	11/12/2024	
24-11-00958-051	M-S-GLR	11/07/2024	GIRLS LOCKER RM SINK	<1.00	11/12/2024	
24-11-00958-052	M-BF-HALL C	11/07/2024	HALL C BOTTLE FILLER	<1.00	11/12/2024	
24-11-00958-053	M-SR	11/07/2024	SUNROOM	<1.00	11/12/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 24-11-00958

Project/Test Address: 2539; 100 Old Stirling Rd; Warren, NJ 07059

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8

Analyst: Nicole Holloway

Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



ENVIRONMENTAL HAZARDS SERVICES, LLC

WaterSmart® Lead Chain-of-Custody Form

Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907
www.leadlab.com

24-11-00958



Due Date:

11/13/2024

(Wednesday)

AE

Client Name: LEW CORP Account #: 201327

Address: 181 US HIGHWAY 46

City/State/Zip: MINE HILL, NJ 07803

Email Address: labresults@lewcorp.com

Project Name/ Number: 2539

Collection Address: 100 Old Stirling Rd City/State/Zip: Warren, NJ 07059
(Required) (Required)

Approx. Age Of Property: _____ Collected By: ERICK ULLOA

Water Source: (Check One) Public ☒ or Well _____

Well Tag # (if applicable): _____

Turn-Around Time

☒

5 Days

☐ 3 Days

☐ 2 Days

☐ 1 Day

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
1	M-WC-Hall C	Hall C, Water Cooler	11-01-2024	AM / PM	X	
2	M-BF-Hall C	Hall C, Bottle Filler		AM / PM	X	
3	3-M-S-Art	Art Rm, Sink		AM / PM	X	
4	4-M-S-Art	Art Rm, Sink		AM / PM	X	
5	M-S-Rm 40	Rm 40, Sink		AM / PM	X	
6	M-S-Rm 42	Rm 42, Sink		AM / PM	X	
7	M-S-Staff	Staff, Sink		AM / PM	X	
8	M-BF-Hall D	Hall D, Bottle Filler		AM / PM	X	
9	M-S-Bath 1	Bath 1, Sink		AM / PM	X	
10	M-S-Bath 2	Bath 2, Sink		AM / PM	X	
11	M-S-Rm 52	Rm 52, Sink		AM / PM	X	
12	M-S-BR	Boiler Rm, Sink		AM / PM	X	
13	M-S-Rm 33	Rm 33, Sink		AM / PM	X	
14	M-WC-Hall C	Hall C, Water Cooler		AM / PM	X	
15	M-S-Bath 3	Bath 3, Sink		AM / PM	X	

Released by: ERICK ULLOA

Signature: _____

Date/Time: 11-01-2024

Received by: EMILY STMAS

Signature: _____

Date/Time: 11/6/24 1204pm

Project Name: **2539**

Lab I.D. #: **00958**

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
16	M-S-Bath 4	Bath 4, Sink	11-01-2024	AM / PM	X	
17	M-BF-Caf	In APR, Bottle Filler		AM / PM	X	
18	M-WC-Caf	In APR, Water Cooler		AM / PM	X	
19	M-BF-Rm 35	Rm 35, Bottle Filler		AM / PM	X	
20	M-WC-Rm 35	Rm 35, Water Cooler		AM / PM	X	
21	M-S-BLR	Boys Locker Rm, Sink		AM / PM	X	
22	M-S-Rm 32	Rm 32, Sink		AM / PM	X	
23	M-S1-Rm 31	Rm 31, Sink		AM / PM	X	
24	M-S2-Rm 31	Rm 31, Sink		AM / PM	X	
25	M-S3-Rm 31	Rm 31, Sink		AM / PM	X	
26	M-S4-Rm 31	Rm 31, Sink		AM / PM	X	
27	M-BF-LH	Library Hall, Bottle Filler		AM / PM	X	
28	M-WC-LH	Library Hall, Water cooler		AM / PM	X	
29	M-S-Rm 25	Rm 25, Sink		AM / PM	X	
30	M-S-SP	Science Prep, Sink		AM / PM	X	
31	M-S-Rm 21	Rm 21, Sink		AM / PM	X	
32	M-BF-LH	By Rm 21, Bottle Filler		AM / PM	X	
33	M-WC-LH	By Rm 21, Water Cooler		AM / PM	X	
34	M-S-Bath 5	Boys Bathroom, Sink		AM / PM	X	
35	M-S-Rm 17	Rm 17, Sink		AM / PM	X	
36	M-BF-Hall A	By Rm 12, Bottle Filler		AM / PM	X	
37	M-WC-Hall A	By Rm 12, Water Cooler		AM / PM	X	
38	M-S-Bath 6	Bath 6, Sink		AM / PM	X	
39	M-S-Rm 7	Rm 7, Sink		AM / PM	X	
40	M-S-IT Rm	IT Rm, Sink		AM / PM	X	
41	M-BF-Hall A	By 6th grade Staff Room, Bottle Filler		AM / PM	X	
42	M-WC-Hall A	By 6th grade Staff Room, Water Cooler		AM / PM		
43	M-S-Staff 2	6th Grade Staff Rm, Sink		AM / PM		
44	M-S-Office	Main Office, Sink		AM / PM		
45	M-WC-Hall B	Hall B, Water Cooler		AM / PM		
46	M-BF-Hall B	Hall B, Bottle Filler		AM / PM		
47	M-S-Bath 7	Bath 7, Sink		AM / PM		
48	M-S-Bath 8	Bath 8, Sink		AM / PM		
49	M-S1-Nurse	Nurse, Sink		AM / PM		
50	M-S2-Nurse	Nurse, Sink		AM / PM		

Released by: ERICK ULLOA Signature:  Date/Time: 11-01-2024
 Received by:  Signature:  Date/Time: 11/6/24 12:04pm

Client Name: **LEW CORP** Account # **201327** Page **3** of **3**

Project Name: **2539**

Lab I.D. #: **00958**


No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
51	M-S-GLR	Girls Locker Rm, Sink	11-01-2024	AM / PM	X	
52	M-BF-HALL C	HALL C, BOTTLE FILLER	I	AM / PM	X	
53	M-SR	SUNROOM	I	AM / PM	X	
				AM / PM	X	
				AM / PM	X	
21				AM / PM	X	
22				AM / PM	X	
23				AM / PM	X	
24				AM / PM	X	
25				AM / PM	X	
26				AM / PM	X	
27				AM / PM	X	
28				AM / PM	X	
29				AM / PM	X	
30				AM / PM	X	
31				AM / PM	X	
32				AM / PM	X	
33				AM / PM	X	
34				AM / PM	X	
35				AM / PM	X	
36				AM / PM	X	
37				AM / PM	X	
38				AM / PM	X	
39				AM / PM	X	
40				AM / PM	X	
41				AM / PM	X	
42				AM / PM		
43				AM / PM		
44				AM / PM		
45				AM / PM		
46				AM / PM		
47				AM / PM		
48				AM / PM		
49				AM / PM		
50				AM / PM		

Released by: ERICK ULLOA

Signature: 

Date/Time: 11-01-2024

Received by: 

Signature: 

Date/Time: 11/6/24 1204pm



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 24-11-01172

Received Date: 11/07/2024
Reported Date: 11/14/2024
Sampled By: Erick Ulloa
Tech Certification #:

Project/Test Address: 2351; 80 Mt Horeb Rd; Warren, NJ 07059

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-01172-001	1MH-S-OFFICE	11/02/2024	MAIN OFFICE SINK	<1.00	11/13/2024	
24-11-01172-002	2MH-S-BATH1	11/02/2024	BOYS BATHROOM SINK	<1.00	11/13/2024	
24-11-01172-003	3MH-S-BATH2	11/02/2024	GIRLS BATHROOM SINK	<1.00	11/13/2024	
24-11-01172-004	4MH-BF-HALLA	11/02/2024	HALL APR BOTTLE FILLER	<1.00	11/13/2024	
24-11-01172-005	5MH-WC-HALLA	11/02/2024	HALL APR WATER COOLER	<1.00	11/13/2024	
24-11-01172-006	6MH-WC-HALLA	11/02/2024	HALL APR WATER COOLER	<1.00	11/13/2024	
24-11-01172-007	7MH-SB-1A	11/02/2024	RM 1A BUBBLER	85.4	11/13/2024	
24-11-01172-008	8MH-SB-2A	11/02/2024	RM 2A BUBBLER	5.34	11/13/2024	
24-11-01172-009	9MH-S-KIT	11/02/2024	KITCHEN SINK	1.49	11/13/2024	
24-11-01172-010	10MH-S-STAFF	11/02/2024	FACULTY LOUNGE SINK	<1.00	11/13/2024	
24-11-01172-011	11MH-SB-3A	11/02/2024	RM 3A BUBBLER	3.03	11/13/2024	
24-11-01172-012	12MH-SB-4A	11/02/2024	RM 4A BUBBLER	13.8	11/13/2024	
24-11-01172-013	13MH-SB-5A	11/02/2024	RM 5A BUBBLER	4.67	11/13/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 24-11-01172

Project/Test Address: 2351; 80 Mt Horeb Rd; Warren, NJ 07059

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-01172-014	14MH-SB-10A	11/02/2024	RM 10A BUBBLER	5.59	11/13/2024	
24-11-01172-015	15MH-SB-6A	11/02/2024	RM 6A BUBBLER	9.83	11/13/2024	
24-11-01172-016	16MH-SB-9A	11/02/2024	RM 9A BUBBLER	<1.00	11/13/2024	
24-11-01172-017	17MH-SB-8A	11/02/2024	RM 8A BUBBLER	1.05	11/13/2024	
24-11-01172-018	18MH-SB-7A	11/02/2024	RM 7A BUBBLER	1.51	11/13/2024	
24-11-01172-019	19MH-S-NURSE	11/02/2024	NURSE SINK	<1.00	11/13/2024	
24-11-01172-020	20MH-SB-2B	11/02/2024	RM 2B BUBBLER	<1.00	11/13/2024	
24-11-01172-021	21MH-SB-16B	11/02/2024	RM 16B BUBBLER	<1.00	11/13/2024	
24-11-01172-022	22MH-SB-3B	11/02/2024	RM 3B BUBBLER	<1.00	11/13/2024	
24-11-01172-023	23MH-SB-13B	11/02/2024	RM 13, BUBBLER	<1.00	11/13/2024	
24-11-01172-024	24MH-BF-HALLB	11/02/2024	HALL B BOTTLE FILLER	1.62	11/13/2024	
24-11-01172-025	25MH-WC-HALLB	11/02/2024	HALL B WATER COOLER	<1.00	11/13/2024	
24-11-01172-026	26MH-S-BATH3	11/02/2024	BOYS BATHROOM SINK	<1.00	11/13/2024	
24-11-01172-027	27MH-S-BATH4	11/02/2024	GIRLS BATHROOM SINK	<1.00	11/13/2024	
24-11-01172-028	28MH-SB-4B	11/02/2024	RM 4B BUBBLER	<1.00	11/13/2024	
24-11-01172-029	29MH-SB-12B	11/02/2024	RM 12B BUBBLER	<1.00	11/13/2024	
24-11-01172-030	30MH-SB-6B	11/02/2024	RM 6B BUBBLER	<1.00	11/13/2024	
24-11-01172-031	31MH-SB-7B	11/02/2024	RM 7B BUBBLER	<1.00	11/13/2024	
24-11-01172-032	32MH-SB-10B	11/02/2024	RM 10B BUBBLER	<1.00	11/13/2024	
24-11-01172-033	33MH-SB-8B	11/02/2024	RM 8B BUBBLER	<1.00	11/13/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 24-11-01172

Project/Test Address: 2351; 80 Mt Horeb Rd; Warren, NJ 07059

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-01172-034	34MH-SB-9B	11/02/2024	RM 9B BUBBLER	<1.00	11/13/2024	
24-11-01172-035	35MH-S-BATH5	11/02/2024	BOYS BATH SINK	<1.00	11/13/2024	
24-11-01172-036	36MH-S-BATH6	11/02/2024	GIRLS BATH SINK	<1.00	11/13/2024	
24-11-01172-037	37MH-BF-HALLC	11/02/2024	HALL C BOTTLE FILLER	<1.00	11/13/2024	
24-11-01172-038	38MH-W-HALLC	11/02/2024	HALL C WATER COOLER	<1.00	11/13/2024	
24-11-01172-039	39MH-WC-HALLC	11/02/2024	HALL C WATER COOLER	<1.00	11/13/2024	
24-11-01172-040	40MH-S-LB	11/02/2024	LIBRARY SINK	2.91	11/13/2024	
24-11-01172-041	42MH-SB-13C	11/02/2024	RM 13C BUBBLER	10.3	11/13/2024	
24-11-01172-042	43MH-SB-12C	11/02/2024	RM 12C BUBBLER	5.17	11/13/2024	
24-11-01172-043	44MH-SB-11C	11/02/2024	RM 11C BUBBLER	3.33	11/13/2024	
24-11-01172-044	46MH-SB-6C	11/02/2024	RM 6C BUBBLER	5.93	11/13/2024	
24-11-01172-045	47MH-SB-10C	11/02/2024	RM 10C BUBBLER	7.41	11/13/2024	
24-11-01172-046	48MH-S-8C	11/02/2024	RM 8C SINK	<1.00	11/13/2024	
24-11-01172-047	49MH-S-BATH7	11/02/2024	BATHROOM SINK	<1.00	11/13/2024	
24-11-01172-048	50MH-S-9C	11/02/2024	RM 9C SINK	1.02	11/13/2024	
24-11-01172-049	51MH-SR	11/02/2024	SUNROOM	<1.00	11/13/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 24-11-01172

Project/Test Address: 2351; 80 Mt Horeb Rd; Warren, NJ 07059

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8

Analyst: Nicole Holloway

Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



ENVIRONMENTAL HAZARDS SERVICES, LLC
WaterSmart® Lead Chain-of-Custody Form
Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907
www.leadlab.com

24-11-01172



Due Date:
11/14/2024
(Thursday)
AE

Client Name: LEW CORP Account #: 201327

Address: 181 US HIGHWAY 46

City/State/Zip: MINE HILL, NJ 07803

Email Address: labresults@lewcorp.com

Project Name/ Number: 2351

Collection Address: 80 MT HOREB RD City/State/Zip: WARREN, NJ 07059
(Required) (Required)

Approx. Age Of Property: _____ Collected By: ERICK ULLOA

Water Source: (Check One) Public ☒ or Well _____

Well Tag # (if applicable): _____

Turn-Around Time

☒

5 Days

☐ 3 Days

☐ 2 Days

☐ 1 Day

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
1	1MH-S-OFFICE	MAIN OFFICE, SINK	11-02-2024	AM / PM	X	
2	2MH-S-BATH1	BOYS BATHROOM, SINK		AM / PM	X	
3	3MH-S-BATH2	GIRLS BATHROOM, SINK		AM / PM	X	
4	4MH-BF-HALLA	HALL APR, BOTTLE FILLER		AM / PM	X	
5	5MH-WC-HALLA	HALL APR, WATER COOLER		AM / PM	X	
6	6MH-WC-HALLA	HALL APR, WATER COOLER		AM / PM	X	
7	7MH-SB-1A	RM 1A, BUBBLER		AM / PM	X	
8	8MH-SB-2A	RM 2A, BUBBLER		AM / PM	X	
9	9MH-S-KIT	KITCHEN, SINK		AM / PM	X	
10	10MH-S-STAFF	FACULTY LOUNGE, SINK		AM / PM	X	
11	11MH-SB-3A	RM 3A, BUBBLER		AM / PM	X	
12	12MH-SB-4A	RM 4A, BUBBLER		AM / PM	X	
13	13MH-SB-5A	RM 5A, BUBBLER		AM / PM	X	
14	14MH-SB-10A	RM 10A, BUBBLER		AM / PM	X	
15	15MH-SB-6A	RM 6A, BUBBLER		AM / PM	X	

Released by: ERICK ULLOA

Signature: _____

Date/Time: 11-02-2024

Received by: ERICK ULLOA

Signature: _____

Date/Time: 11/7/24 1142am



Project Name: **2351**Lab I.D. #: **01172**

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
16	16MH-SB-9A	RM9A, BUBBLER		AM / PM	X	
17	17MH-SB-8A	RM 8A, BUBBLER		AM / PM	X	
18	18MH-SB-7A	RM 7A, BUBBLER		AM / PM	X	
19	19MH-S-NURSE	NURSE, SINK		AM / PM	X	
20	20MH-SB-2B	RM 2B, BUBBLER		AM / PM	X	
21	21MH-SB-16B	RM 16B, BUBBLER		AM / PM	X	
22	22MH-SB-3B	RM 3B, BUBBLER		AM / PM	X	
23	23MH-SB-13B	RM 13B, BUBBLER		AM / PM	X	
24	24MH-BF-HALLB	HALL B, BOTTLE FILLER		AM / PM	X	
25	25MH-WC-HALLB	HALL B, WATER COOLER		AM / PM	X	
26	26MH-S-BATH3	BOYS BATHROOM, SINK		AM / PM	X	
27	27MH-S-BATH4	GIRLS BATHROOM, SINK		AM / PM	X	
28	28MH-SB-4B	RM 4B, BUBBLER		AM / PM	X	
29	29MH-SB-12B	RM 12B, BUBBLER		AM / PM	X	
30	30MH-SB-6B	RM 6B, BUBBLER		AM / PM	X	
31	31MHSB-7B	RM 7B, BUBBLER		AM / PM	X	
32	32MH-SB-10B	RM 10B, BUBBLER		AM / PM	X	
33	33MH-SB-8B	RM 8B, BUBBLER		AM / PM	X	
34	34MH-SB-9B	RM 9B, BUBBLER		AM / PM	X	
35	35MH-S-BATH5	BOY BATH, SINK		AM / PM	X	
36	36MH-S-BATH6	GIRLS BATH, SINK		AM / PM	X	
37	37MH-BF-HALLC	HALL C, BOTTLE FILLER		AM / PM	X	
38	38MH-W-HALLC	HALL C, WATER COOLER		AM / PM	X	
39	39MH-WC-HALLC	HALL C, WATER COOLER		AM / PM	X	
40	40MH-S-L B	LIBRARY, SINK		AM / PM	X	
41	42MH-SB-13C	RM 13C, BUBBLER		AM / PM	X	
42	43MH-SB-12C	RM 12C, BUBBLER		AM / PM		
43	44MH-SB-11C	RM 11C, BUBBLER		AM / PM		
44	46MH-SB-6C	RM 6C, BUBBLER		AM / PM		
45	47MH-SB-10C	RM 10C, BUBBLER		AM / PM		
46	48MH-S-8C	RM 8C, SINK		AM / PM		
47	49MH-S-BATH7-	BATHROOM, SINK		AM / PM		
48	50MH-S-9C	RM 9C, SINK		AM / PM		
49	51MH-SR	SUNROOM		AM / PM		
50				AM / PM		

Released by: ERICK ULLOA

Signature: 

Date/Time: 11-09-2024

Received by: Signature: 

Date/Time: 11/7/24 1142Am



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 24-11-01503

Received Date: 11/08/2024
Reported Date: 11/14/2024
Sampled By: Erick Ulloa
Tech Certification #:

Project/Test Address: 2539; 213 Mt Horeb Rd; Warren, NJ 07059

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-01503-001	1-BOE-F-KIT	11/03/2024	KITCHEN SINK	<1.00	11/13/2024	
24-11-01503-002	4-BOE-BF-HALL	11/03/2024	HALL BOTTLE FILLER	<1.00	11/13/2024	
24-11-01503-003	BOE-SR	11/03/2024	SUNROOM	<1.00	11/13/2024	

Method: EPA 200.8
Analyst: Nicole Holloway
Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



ENVIRONMENTAL HAZARDS SERVICES, LLC

WaterSmart® Lead Chain-of-Custody Form

Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907

www.leadlab.com

24-11-01503



Due Date:

11/15/2024

(Friday)

AE

Client Name: LEW CORP Account #: 201327

Address: 181 US HIGHWAY 46

City/State/Zip: MINE HILL, NJ 07803

Phone: 908-654-8068

Email Address: labresults@lewcorp.com

Project Name/ Number: 2539

Collection Address: 213 MT HOREB, RD
(Required)

City/State/Zip: WARREN, NJ 07059
(Required)

Approx. Age Of Property: _____ Collected By: ERICK ULLOA

Water Source: (Check One) Public ☒ or Well _____

Well Tag # (if applicable): _____

Turn-Around Time

☒

5 Days

☐ 3 Days

☐ 2 Days

☐ 1 Day

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
1	1-BOE-F-KIT	KITCHEN, SINK	11-03-2024	AM / PM	X	
2	4-BOE-BF-HALL	HALL, BOTTLE FILLER		AM / PM	X	
3	BOE-SR	SUNROOM		AM / PM	X	
4				AM / PM	X	
5				AM / PM	X	
6				AM / PM	X	
7				AM / PM	X	
8				AM / PM	X	
9				AM / PM	X	
10				AM / PM	X	
11				AM / PM	X	
12				AM / PM	X	
13				AM / PM	X	
14				AM / PM	X	
15				AM / PM	X	

Released by: ERICK ULLOA

Signature: [Signature]

Date/Time: 11-03-2024

Received by: CHRISTMAS

Signature: [Signature]

Date/Time: 11/8/24 1232 pm



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 24-11-01508

Received Date: 11/08/2024
Reported Date: 11/14/2024
Sampled By: Erick Ulloa
Tech Certification #:

Project/Test Address: 2539; 109 Mt Bethel Rd; Warren, NJ 07059

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-01508-001	2-C-S-BATH1	11/03/2024	BOYS BATH SINK	6.12	11/13/2024	
24-11-01508-002	3-C-S-BATH2	11/03/2024	GIRLS BATH SINK	<1.00	11/13/2024	
24-11-01508-003	4-C-S-ART	11/03/2024	ART SINK	<1.00	11/13/2024	
24-11-01508-004	5-C-S-KIT	11/03/2024	KITCHEN SINK	1.59	11/13/2024	
24-11-01508-005	6-C-S-BATH3	11/03/2024	GIRLS BATH SINK	1.15	11/13/2024	
24-11-01508-006	7-C-S-NURSE	11/03/2024	NURSE SINK	<1.00	11/13/2024	
24-11-01508-007	8-C-S-BATH4	11/03/2024	NURSE LARGE BATH SINK	<1.00	11/13/2024	
24-11-01508-008	9-C-S-BATH5	11/03/2024	NURSE SMALL BATH SINK	1.79	11/13/2024	
24-11-01508-009	11A-C-WC-MH	11/03/2024	MAIN HALL FACULTY RM WATER COOLER	<1.00	11/13/2024	
24-11-01508-010	11B-C-BF-MH	11/03/2024	MAIN HALL FACULTY RM BOTTLE FILLER	<1.00	11/13/2024	
24-11-01508-011	12-C-S-MH	11/03/2024	STAFF RM SINK	<1.00	11/13/2024	
24-11-01508-012	13-C-S-BATH6	11/03/2024	BOYS BATH SINK	<1.00	11/13/2024	
24-11-01508-013	15C-S-BATH7	11/03/2024	GIRLS BATH SINK	1.58	11/13/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 24-11-01508

Project/Test Address: 2539; 109 Mt Bethel Rd; Warren, NJ 07059

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-01508-014	16-C-S-BATH8	11/03/2024	BOYS BATH SINK	<1.00	11/13/2024	
24-11-01508-015	17A-C-WC-HALLA	11/03/2024	PUMP ROOM HALL WATER COOLER	<1.00	11/13/2024	
24-11-01508-016	17B-C-WC-HALLA	11/03/2024	PUMP ROOM HALL WATER COOLER	<1.00	11/13/2024	
24-11-01508-017	18-C-B-RM14	11/03/2024	ROOM 14 BUBBLER	2.03	11/13/2024	
24-11-01508-018	21-C-B-RM16	11/03/2024	ROOM 16 BUBBLER	4.65	11/13/2024	
24-11-01508-019	25-C-S-BATH9	11/03/2024	GIRLS BATH SINK	<1.00	11/13/2024	
24-11-01508-020	26-C-S-BATH10	11/03/2024	BOYS BATH SINK	<1.00	11/13/2024	
24-11-01508-021	30-C-B-HALLC	11/03/2024	HALL C BUBBLER	2.75	11/13/2024	
24-11-01508-022	32-C-B-RM24	11/03/2024	ROOM 24 BUBBLER	1.71	11/13/2024	
24-11-01508-023	33A-C-B-HALLC	11/03/2024	HALL C BOTTLE FILLER	<1.00	11/13/2024	
24-11-01508-024	33B-C-WC-HALLC	11/03/2024	HALL C WATER COOLER	<1.00	11/13/2024	
24-11-01508-025	36-C-B-RM29	11/03/2024	ROOM 29 BUBBLER	3.48	11/13/2024	
24-11-01508-026	37-C-B-RM26	11/03/2024	ROOM 26 BUBBLER	<1.00	11/13/2024	
24-11-01508-027	39-C-B-RM27	11/03/2024	ROOM 27 BUBBLER	166	11/13/2024	
24-11-01508-028	40-C-B-APR	11/03/2024	ALL PURPOSE ROOM BOTTLE FILLER	<1.00	11/13/2024	
24-11-01508-029	41-C-WC-APR	11/03/2024	ALL PURPOSE ROOM WATER COOLER	<1.00	11/13/2024	
24-11-01508-030	42-C-SR	11/03/2024	SUNROOM	<1.00	11/13/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 24-11-01508

Project/Test Address: 2539; 109 Mt Bethel Rd; Warren, NJ 07059

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8

Analyst: Nicole Holloway

Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



ENVIRONMENTAL HAZARDS SERVICES, LLC

WaterSmart® Lead Chain-of-Custody Form

Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907
www.leadlab.com

24-11-01508



Due Date:
11/15/2024
(Friday)
AE

Client Name: LEW CORP Account #: 201327

Address: 181 US HIGHWAY 46

City/State/Zip: MINE HILL, NJ 07803

Phone: 908-654-8068

Email Address: labresults@lewcorp.com

Project Name/ Number: 2539

Collection Address: 109 MT BETHEL RD

City/State/Zip: Warren, NJ 07059

(Required)

(Required)

Approx. Age Of Property: _____ Collected By: ERICK ULLOA

Water Source: (Check One) Public ☒ or Well _____

Well Tag # (if applicable): _____

Turn-Around Time

☒

5 Days

☐ 3 Days

☐ 2 Days

☐ 1 Day

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
1	2-C-S-BATH1	BOYS BATH, SINK	11-3-2024	AM / PM	X	
2	3-C-S-BATH2	GIRLS BATH, SINK		AM / PM	X	
3	4-C-S-ART	ART, SINK		AM / PM	X	
4	5-C-S-KIT	KITCHEN SINK, SINK		AM / PM	X	
5	6-C-S-BATH3	GIRLS BATH, SINK		AM / PM	X	
6	7-C-S-NURSE	NURSE SINK, SINK		AM / PM	X	
7	8-C-S-BATH4	NURSE LARGE BATH, SINK		AM / PM	X	
8	9-C-S-BATH5	NURSE SMALL BATH, SINK		AM / PM	X	
9	10-C-WC-MH	MAIN HALL, WATER COOLER	* sample not received	ECC 11/3/24	AM / PM	X
10	11A-C-WC-MH	MAIN HALL FACULTY RM, WATER COOLER		AM / PM	X	
11	11B-C-BF-MH	MAIN HALL FACULTY RM, BOTTLE FILLER		AM / PM	X	
12	12-C-S-MH	STAFF RM, SINK		AM / PM	X	
13	13-C-S-BATH 6	BOYS BATH, SINK		AM / PM	X	
14	15-C-S-BATH7	GIRLS BATH, SINK		AM / PM	X	
15	16-C-S-BATH8	BOYS BATH, SINK		AM / PM	X	

Released by: ERICK ULLOA

Signature: _____

Date/Time: 11-03-2024

Received by: CHRISTMAS

Signature: _____

Date/Time: 11/3/24 1238pm

Client Name: **LEW CORP** Account # **201327** Page **2** of **2**

Project Name: **2539**

Lab I.D. #: **01508**

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
51	17A-C-WC- HALL A	PUMP ROOM HALL, WATER COOLER	11-3-2024	AM / PM	X	
52	17B-C-WC- HALL A	PUMP ROOM HALL, WATER COOLER		AM / PM	X	
53	18-C-B-RM14	ROOM 14, BUBBLER		AM / PM	X	
54	19-C-B-RM15	ROOM 15, BUBBLER	<i>+ sample not received at ERULL/S</i>	AM / PM	X	
55	21-C-B-RM16	ROOM 16, BUBBLER		AM / PM	X	
56	25-C-S-BATH9	GIRLS BATH, SINK		AM / PM	X	
57	26-C-S-BATH10	BOOYS BATH, SINK		AM / PM	X	
58	30-C-B-HALLC	HALL C, BUBBLER		AM / PM	X	
59	32-C-B-RM24	ROOM 24, BUBBLER		AM / PM	X	
60	33A-C-B-HALLC	HALL C, BOTTLE FILLER		AM / PM	X	
61	33B-C-WC-HALLC	HALL C, WATER COOLER		AM / PM	X	
62	36-C-B-RM29	ROOM 29, BUBBLER		AM / PM	X	
63	37-C-B-RM26	ROOM 26, BUBBLER		AM / PM	X	
64	39-C-B-RM27	ROOM 27, BUBBLER		AM / PM	X	
65	40-C-B-APR	ALL PURPOSE ROOM, BOTTLE FILLER		AM / PM	X	
66	41-C-WC-APR	ALL PURPOSE ROOM, WATER COOLER		AM / PM	X	
67	42-C-SR	SUNROOM		AM / PM	X	
68				AM / PM	X	
69				AM / PM	X	
70				AM / PM	X	
71				AM / PM	X	
72				AM / PM	X	
73				AM / PM	X	
74				AM / PM	X	
75				AM / PM	X	
76				AM / PM	X	
77				AM / PM		
78				AM / PM		
79				AM / PM		
80				AM / PM		
81				AM / PM		
82				AM / PM		
83				AM / PM		
84				AM / PM		
85				AM / PM		

Released by: ERICK ULLOA	Signature: 	Date/Time: 11-03-2024
Received by: 	Signature: 	Date/Time: 11/8/24 1230pm



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 24-11-01167

Received Date: 11/07/2024
Reported Date: 11/14/2024
Sampled By: Erick Ulloa
Tech Certification #:

Project/Test Address: 2351; 114 Stirling Rd; Warren, NJ 07059

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-01167-001	W-SB-RM2	11/03/2024	RM 2 SINK/BUBBLER	<1.00	11/12/2024	
24-11-01167-002	W-SB-RM3	11/03/2024	RM 3 SINK/BUBBLER	4.06	11/12/2024	
24-11-01167-003	W-SB-RM5	11/03/2024	RM 5 SINK/BUBBLER	<1.00	11/12/2024	
24-11-01167-004	W-SB-RM4	11/03/2024	RM 4 SINK/BUBBLER	<1.00	11/12/2024	
24-11-01167-005	W-S-BATH1	11/03/2024	BOYS BATH BY STAFF SINK	2.09	11/12/2024	
24-11-01167-006	W-S-STAFF	11/03/2024	FACULTY ROOM SINK/BUBBLER	15.3	11/13/2024	
24-11-01167-007	W-BF-HALLA	11/03/2024	BOTTLE FILLER BY FACULTY BOTTLE FILLER	<1.00	11/12/2024	
24-11-01167-008	W-WC-HALLA	11/03/2024	WATER COOLER BY FACULTY WATER COOLER	<1.00	11/12/2024	
24-11-01167-009	W-S-BATH 2	11/03/2024	GIRLS BATH BY STAFF ROOM SINK	3.01	11/12/2024	
24-11-01167-010	W-S-BATH 3	11/03/2024	BATH BY ROOM 7 SINK	2.58	11/12/2024	
24-11-01167-011	W-SB-RM7	11/03/2024	RM 7 BUBBLER	8.72	11/12/2024	
24-11-01167-012	W-SB-RM10	11/03/2024	RM 10 BUBBLER	<1.00	11/12/2024	
24-11-01167-013	W-SB1-RM9	11/03/2024	RM 9 BUBBLER	<1.00	11/12/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 24-11-01167

Project/Test Address: 2351; 114 Stirling Rd; Warren, NJ 07059

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-01167-014	W-SB2-RM9	11/03/2024	IN BETWEEN RM 9 BUBBLER	3.43	11/12/2024	
24-11-01167-015	W-S1-KITCHEN	11/03/2024	KITCHEN SINK 1	3.64	11/12/2024	
24-11-01167-016	W-S2-KITCHEN	11/03/2024	KITCHEN SINK 2	<1.00	11/13/2024	
24-11-01167-017	W-BF-CAF	11/03/2024	BOTTLE FILLER IN APR BOTTLE FILLER	<1.00	11/12/2024	
24-11-01167-018	W-WC-CAF	11/03/2024	WATER COOLER IN APR WATER COLLER	<1.00	11/12/2024	
24-11-01167-019	W-S1-NURSE	11/03/2024	NURSE SINK1	<1.00	11/12/2024	
24-11-01167-020	W-S2-NURSE	11/03/2024	NURSE SINK2	3.38	11/12/2024	
24-11-01167-021	W-SB-RM12	11/03/2024	RM 12 SINK/BUBBLER	10.0	11/13/2024	
24-11-01167-022	W-S-BATH4	11/03/2024	GIRLS BATH LOWER WING SINK	1.37	11/12/2024	
24-11-01167-023	W-S-BATH5	11/03/2024	BOYS BATH LOWER WING SINK	<1.00	11/12/2024	
24-11-01167-024	W-SB-RM23	11/03/2024	RM 23 BUBBLER	4.53	11/12/2024	
24-11-01167-025	W-SB-RM22	11/03/2024	RM 22 BUBBLER	<1.00	11/12/2024	
24-11-01167-026	W-SB-RM24	11/03/2024	RM 24 BUBBLER	1.80	11/12/2024	
24-11-01167-027	W-SB-RM27	11/03/2024	RM 27 BUBBLER	1.29	11/12/2024	
24-11-01167-028	W-BF-HALLB	11/03/2024	BY RM 27 BOTTLE FILLER	<1.00	11/12/2024	
24-11-01167-029	W-WC-HALLB	11/03/2024	BY RM 27 WATER COOLER	<1.00	11/12/2024	
24-11-01167-030	W-SB-RM26	11/03/2024	RM 26 BUBBLER	1.26	11/12/2024	
24-11-01167-031	W-SB-RM29	11/03/2024	RM 29 BUBBLER	1.60	11/12/2024	
24-11-01167-032	W-SB-RM28	11/03/2024	RM 28 BUBBLER	<1.00	11/12/2024	
24-11-01167-033	W-SB-RM30	11/03/2024	RM 30 BUBBLER	<1.00	11/12/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 24-11-01167

Project/Test Address: 2351; 114 Stirling Rd; Warren, NJ 07059

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-01167-034	W-SB-RM32	11/03/2024	RM 32 BUBBLER	<1.00	11/12/2024	
24-11-01167-035	W-S1-RM34	11/03/2024	RM 34 SINK 1	2.48	11/12/2024	
24-11-01167-036	W-S2-RM34	11/03/2024	RM 34 SINK 2	1.88	11/12/2024	
24-11-01167-037	W-S-BATH6	11/03/2024	BOYS BATH BY LIBRARY SINK	3.84	11/12/2024	
24-11-01167-038	W-S-BATH7	11/03/2024	GIRLS BATH BY LIBRARY SINK	1.21	11/12/2024	
24-11-01167-039	W-S-LIB	11/03/2024	LIBRARY SINK	2.61	11/12/2024	
24-11-01167-040	W-BF-HALLC	11/03/2024	BY GYM BOTTLE FILLER	<1.00	11/12/2024	
24-11-01167-041	W-WC-HALLC	11/03/2024	BY GYM WATER COOLER	<1.00	11/12/2024	
24-11-01167-042	W-S-BATH8	11/03/2024	BATH 8 SINK	<1.00	11/12/2024	
24-11-01167-043	W-SR	11/03/2024	SUNROOM	3.91	11/12/2024	

Method: EPA 200.8

Analyst: Nicole Holloway

Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

**ENVIRONMENTAL HAZARDS SERVICES, LLC****WaterSmart® Lead Chain-of-Custody Form**

Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907

www.leadlab.com

24-11-01167



Due Date:

11/14/2024

(Thursday)

AE

Client Name: **LEW CORP** Account #: **201327**Address: **181 US HIGHWAY 46**City/State/Zip: **MINE HILL, NJ 07803**Phone: **908-654-8068**Email Address: **labresults@lewcorp.com**Project Name/ Number: **2351**Collection Address: **114 STIRLING RD**
(Required)City/State/Zip: **WARREN NJ 07059**
(Required)Approx. Age Of Property: _____ Collected By: **ERICK ULLOA**Water Source: (Check One) Public ☒ or Well _____ Well Tag # (if applicable): _____Turn-Around Time ☒ 5 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
1	W-SB-RM2	RM 2, SINK/BUBBLER	11-03-2024	AM / PM	X	
2	W-SB-RM3	RM 3, SINK/BUBBLER		AM / PM	X	
3	W-SB-RM5	RM 5, SINK/BUBBLER		AM / PM	X	
4	W-SB-RM4	RM 4, SINK/BUBBLER		AM / PM	X	
5	W-S-BATH1	BOYS BATH BY STAFF, SINK		AM / PM	X	
6	W-S-STAFF	FACULTY ROOM, SINK/BUBBLER		AM / PM	X	
7	W-BF-HALL A	BOTTLE FILLER BY FACULTY, BOTTLE FILLER		AM / PM	X	
8	W-WC-HALL A	WATER COOLER BY FACULTY, WATER COOLER		AM / PM	X	
9	W-S-BATH 2	GIRLS BATH BY STAFF ROOM, SINK		AM / PM	X	
10	W-S-BATH 3	BATH BY ROOM 7, SINK		AM / PM	X	
11	W-SB-RM 7	RM 7, BUBBLER		AM / PM	X	
12	W-SB-RM10	RM 10, BUBBLER		AM / PM	X	
13	W-SB1-RM9	RM 9, BUBBLER		AM / PM	X	
14	W-SB2-RM9	IN BETWEEN RM 9, BUBBLER		AM / PM	X	
15	W-S1-KITCHEN	KITCHEN, SINK 1		AM / PM	X	

Released by: **ERICK ULLOA**

Signature:

Date/Time: **11-03-2024**

Received by:

Signature:

Date/Time: **11/7/24 11:14am**

Project Name: **2351**


Lab I.D. #: **01167**

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
16	W-S2-KITCHEN	KITCHEN, SINK 2	11-03-2021	AM / PM	X	
17	W-BF-CAF	BOTTLE FILLER IN APR, BOTTLE FILLER		AM / PM	X	
18	W-WC-CAF	WATER COOLER IN APR, WATER COOLER		AM / PM	X	
19	W-S1-NURSE	NURSE, SINK1		AM / PM	X	
20	W-S2-NURSE	NURSE, SINK2		AM / PM	X	
21	W-SB-RM12	RM 12, SINK/BUBBLER		AM / PM	X	
22	W-S-BATH4	GIRLS BATH LOWER WING, SINK		AM / PM	X	
23	W-S-BATH5	BOYS BATH LOWER WING, SINK		AM / PM	X	
24	W-SB-RM23	RM 23, BUBBLER		AM / PM	X	
25	W-SB-RM22	RM 22, BUBBLER		AM / PM	X	
26	W-SB-RM24	RM 24, BUBBLER		AM / PM	X	
27	W-SB-RM27	RM 27, BUBBLER		AM / PM	X	
28	W-BF-HALLB	BY RM27, BOTTLE FILLER		AM / PM	X	
29	W-WC-HALLB	BY RM27, WATER COOLER		AM / PM	X	
30	W-SB-RM26	RM 26, BUBBLER		AM / PM	X	
31	W-SB-RM29	RM 29, BUBBLER		AM / PM	X	
32	W-SB-RM28	RM 28, BUBBLER		AM / PM	X	
33	W-SB-RM30	RM 30, BUBBLER		AM / PM	X	
34	W-SB-RM32	RM 32, BUBBLER		AM / PM	X	
35	W-S1-RM34	RM 34, SINK 1		AM / PM	X	
36	W-S2-RM34	RM 34, SINK 2		AM / PM	X	
37	W-S-BATH6	BOYS BATH BY LIBRARY, SINK		AM / PM	X	
38	W-S-BATH7	GIRLS BATH BY LIBRARY, SINK		AM / PM	X	
39	W-S-LIB	LIBRARY, SINK		AM / PM	X	
40	W-BF-HALLC	BY GYM, BOTTLE FILLER		AM / PM	X	
41	W-WC-HALLC	BY GYM, WATER COOLER		AM / PM	X	
42	W-S-BATH8	BATH 8, SINK		AM / PM		
43	W-SR	SUNROOM		AM / PM		
44				AM / PM		
45				AM / PM		
46				AM / PM		
47				AM / PM		
48				AM / PM		
49				AM / PM		
50				AM / PM		

Released by: ERICK ULLOA

Signature: 

Date/Time: 11-03-2024

Received by: 

Signature: 

Date/Time: 11/7/24 11:14pm



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Report Number: 24-11-01497

Received Date: 11/08/2024
Reported Date: 11/14/2024
Sampled By: Erick Ulloa
Tech Certification #:

Project/Test Address: 2539; Stirling Rd; Warren, NJ 07059

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-11-01497-001	BG-S-KIT	11/03/2024	KITCHEN SINK	1.08	11/13/2024	
24-11-01497-002	BG-SR	11/03/2024	SUNROOM	<1.00	11/13/2024	

Method: EPA 200.8
Analyst: Nicole Holloway
Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



ENVIRONMENTAL HAZARDS SERVICES, LLC

WaterSmart® Lead Chain-of-Custody Form

Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907
www.leadlab.com

24-11-01497



Due Date:
11/15/2024
(Friday)
AE

10+

Phone: 908-654-8068

Client Name: LEW CORP Account #: 201327

Address: 181 US HIGHWAY 46

City/State/Zip: MINE HILL, NJ 07803

Email Address: labresults@lewcorp.com

Project Name/ Number: 2539

Collection Address: Stirling Rd
(Required)

City/State/Zip: Warren, NJ 07059
(Required)

Approx. Age Of Property: Collected By: ERICK ULLOA

Water Source: (Check One) Public ☒ or Well ☐ Well Tag # (if applicable):

Turn-Around Time ☒ 5 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
1	BG-S-KIT	KITCHEN, SINK	11-3-2024	AM / PM	X	
2	BG-SR	SUNROOM		AM / PM	X	
3				AM / PM	X	
4				AM / PM	X	
5				AM / PM	X	
6				AM / PM	X	
7				AM / PM	X	
8				AM / PM	X	
9				AM / PM	X	
10				AM / PM	X	
11				AM / PM	X	
12				AM / PM	X	
13				AM / PM	X	
14				AM / PM	X	
15				AM / PM	X	

Released by: ERICK ULLOA

Signature:

Date/Time: 11-03-2024

Received by: ECHRISTMAS

Signature:

Date/Time: 11/15/24 1226pm