

## Test Report: Lead in Water by Furnace AAS (EPA 200.9)

Client Sample Descrip	ntion Lab ID	Collected	Analyzed		Lead Concentration
33-M-WF-RM17	201709633-0001		9/28/2017		19.1 ppb
Site: Room 17 Science Room - Initial - Faucet					
36-M-WF-RM7	201709633-0002		9/28/2017		3.93 ppb
Site: Room 7 Science Room - Initial - Faucet					

Him Cu. all

Phillip Worby, Lead Laboratory Manager or other approved signatory

The test results contained within this report meet the requirements of NELAC unless otherwise noted. This report relates only to those items tested. Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted. "<" (less than) result signifies that the analyte was not detected at or above the reporting limit. Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NJ-NELAP 03036

Initial report from 10/03/2017 10:14:01