



556 South Mansfield Street
Ypsilanti, MI 48197
1-800-604-1995

Lead Only

Analysis Report

Customer: LEW Corp
1090 Bristol Rd
Mountainside NJ 07092

Report Number: 16-11-03204
Received Date: 11/15/2016
Reported Date: 12/8/2016
Sampled By: Neil Wendt
Tech. Certification #:

P.O. Number: 160857

Project Test/Address: Mt Horeb School; 80 Mt Horeb Rd, Warren, NJ 07059

Client Number: 201327

Report Notes

Sample #	Sample ID	Method	Parameter	Level Detected	EPA Standard	Units	LRL	Sampled	Analyzed
744113	01-MH-S-Office Office	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/22/2016
744114	02-MH-S-Bath1 Bath 1	200.8	Lead	2	15	ug/L	1	11/11/2016	11/22/2016
744115	03-MH-S-Bath2 Bath 2	200.8	Lead	2	15	ug/L	1	11/11/2016	11/22/2016
744116	04-MH-WC-Hall A Hall A	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/22/2016
744117	05-MH-WC-Hall A Hall A	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/29/2016
744118	06-MH-SB-Rm1A Room 1A	200.8	Lead	12	15	ug/L	1	11/11/2016	11/29/2016
744119	07-MH-SB-Rm2A Room 2A	200.8	Lead	3	15	ug/L	1	11/11/2016	11/29/2016
744120	08-MH-S-Kit Kitchen	200.8	Lead	2	15	ug/L	1	11/11/2016	11/29/2016
744121	09-MH-S-Staff Staff	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/29/2016
744122	10-MH-SB-Rm3A Room 3A	200.8	Lead	14	15	ug/L	1	11/11/2016	11/30/2016
744123	11-MH-SB-4A Rm 4A	200.8	Lead	5	15	ug/L	1	11/11/2016	11/30/2016
744124	12-MH-SB-5A Rm 5A	200.8	Lead	5	15	ug/L	1	11/11/2016	11/30/2016
744125	13-MH-SB-10A Rm 10A	200.8	Lead	5	15	ug/L	1	11/11/2016	11/30/2016
744126	14-MH-SB-6A Rm 6A	200.8	Lead	5	15	ug/L	1	11/11/2016	11/30/2016
744127	15-MH-SB-9A Rm 9A	200.8	Lead	1	15	ug/L	1	11/11/2016	11/30/2016
744128	16-MH-SB-8A Rm 8A	200.8	Lead	4	15	ug/L	1	11/11/2016	11/30/2016
744129	17-MH-SB-7A Rm 7A	200.8	Lead	6	15	ug/L	1	11/11/2016	11/30/2016
744130	18-MH-S-Nurse Nurse	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744131	19-MH-SB-2B Room 2B	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744132	20-MH-SB-16B	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744133	21-MH-SB-3B Room 3B	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744134	22-MH-SB-13B Rm 13B	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744135	23-MH-WC-Hall B Hall B	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744136	24-MH-WC-Hall B Hall B	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016

Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc. were provided by the client. This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, LTD.

Sample #	Sample ID	Method	Parameter	Level		Units	LRL	Sampled	Analyzed
				Detected	EPA Standard				
744137	25-MH-S-Bath 3 Bath 3	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744138	26-MH-S-Bath 4 Bath 4	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744139	27-MH-SB-4B Room 4B	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744140	28-MH-SB-12B Rm 12B	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744141	29-MH-SB-6B Rm 6B	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744142	30-MH-SB-7B Rm 7B	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744143	31-MH-SB-10B Room 10B	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744144	32-MH-SB-8B Rm 8B	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744145	33-MH-SB-9B Rm 9B	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744146	34-MH-S-Bath 5 Bath 5	200.8	Lead	3	15	ug/L	1	11/11/2016	11/30/2016
744147	35-MH-S-Bath 6 Bath 6	200.8	Lead	3	15	ug/L	1	11/11/2016	11/30/2016
744148	36-MH-WC-HallC Hall C	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744149	37-MH-WC-HallC Hall C	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744150	38-MH-S-Lib Library	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744151	39-MH-SB-14C Rm 14C	200.8	Lead	5	15	ug/L	1	11/11/2016	11/30/2016
744152	40-MH-SB-13C Rm 13C	200.8	Lead	3	15	ug/L	1	11/11/2016	11/30/2016
744153	41-MH-SB-12C Rm 12C	200.8	Lead	7	15	ug/L	1	11/11/2016	11/30/2016
744154	42-MH-S-11C Rm 11C	200.8	Lead	5	15	ug/L	1	11/11/2016	11/30/2016
744155	43-MH-SB-5C Rm 5C	200.8	Lead	5	15	ug/L	1	11/11/2016	11/30/2016
744156	44-MH-SB-6C Rm 6C	200.8	Lead	6	15	ug/L	1	11/11/2016	11/30/2016
744157	45-MH-SB-10C Rm 10C	200.8	Lead	2	15	ug/L	1	11/11/2016	11/30/2016
744158	46-MH-S-8C Rm 8C	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744159	47-MH-S-Bath 7 Bath 7	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016
744160	48-MH-S-9C Rm 9C	200.8	Lead	3	15	ug/L	1	11/11/2016	11/30/2016
744161	49-MH-B Mt. Horeb Blank	200.8	Lead	ND	15	ug/L	1	11/11/2016	11/30/2016

Analyst	Tests
JP	200.8

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty for the test results are available upon request. All Dates and Times are reported as Eastern Time.

Legend:

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL).
- "NA" Not analyzed.
- "EPA Standard" This column indicates the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "P/A" Presence/Absence

Reviewed by Authorized Signatory



Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc. were provided by the client. This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, LTD.