Laboratory Certification #: MI859



Quality Water Analysis

556 South Mansfield Street

566 South Mansfield Street 1-800-604-1995

Customer:

LEW Corp

1090 Bristol Rd

Mountainside, NJ 07092

Lead Only

Analysis Report

Report Number:

17-03-04510

Received Date:

03/30/2017

Reported Date:

04/12/2017

Sampled By:

Raheen Holland

Tech Certification #:

P.O. Number:

Project Test/Address:

160857; Central School; 109 Mt Bethel Rd; Warren, NJ

Client Number:

Report Notes

Sample #	Sample ID	Method	Parameter	Level Detected	EPA Standards	Units	LRL	Date Sampled I	Date Analyzed
746072	109-18 Rm #14- SB	3113B	Lead	5	15	ug/L	1	03/25/2017	04/10/2017
746073	109-19 Room #15 -SB	3113B	Lead	6	15	ug/L	1	03/25/2017	04/10/2017
746074	109-34 Room #25 -SB	3113B	Lead	6	15	ug/L	İ	03/25/2017	04/10/2017
746075	109-36 Room #29 -SB	3113B	Lead	6	15	ug/L	1	03/25/2017	04/10/2017
746076	109-37 Room #26 -SB	3113B	Lead	3	15	ug/L	1	03/25/2017	04/10/2017
746077	109 Sun Rm-S	3113B	Lead	ND	15	ug/L	1	03/25/2017	04/10/2017
Analyst Tests									

Anaiys

принципальный пре

3113B

DD

The results herin conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as Eastern Time.

Legend:

"ND"

This contaminant was not detected at or above our lower reporting limit (LRL).

"NA"

Not analyzed.

"EPA Standard"

This column indicates the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for

EPA Secondary Standards.

"LRL"

This column indicates the Lower Reporting Limit, which in the lowest level that the laboratory can detect a contaminant.

"PIA"

Presence/Absence

Reviewed by Authorized Signatory

Laboratory Certification #: MI859

Mational Testing Laboratories, Ltd.

> Quality Water Analysis 556 South Mansfield Street Ypsilanti, MI 48197 1-800-604-1995

Lead Only

Analysis Report