

Laboratory Certification #: MI859



Quality Water Analysis

556 South Mansfield Street  
Ypsilanti, MI 48197  
1-800-604-1996

### Lead Only

## Analysis Report

**Customer:** LEW Corp  
1090 Bristol Rd  
Mountainside, NJ 07092

**Report Number:** 17-03-04515  
**Received Date:** 03/30/2017  
**Reported Date:** 04/12/2017  
**Sampled By:** Raheen Holland  
**Tech Certification #:**

**P.O. Number:**

**Project Test/Address:** 160857; Woodland School; 114 Stirling Rd; Warren, NJ

**Client Number:**

**Report Notes**

Sample #	Sample ID	Method	Parameter	Level Detected	EPA Standards	Units	LRL	Date Sampled	Date Analyzed
746082	114-5 Bath Rm #1 -S	3113B	Lead	70	15	ug/L	1	03/25/2017	04/10/2017
746083	114-37 Bath Rm #6-S	3113B	Lead	24	15	ug/L	1	03/25/2017	04/10/2017
746084	114 Sun Rm-S	3113B	Lead	ND	15	ug/L	1	03/25/2017	04/10/2017

Analyst	Tests
DD	3113B

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as Eastern Time.

**Legend:**

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL).
- "NA" Not analyzed.
- "EPA Standard" This column indicates the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "P/A" Presence/Absence

Reviewed by Authorized Signatory

Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc. were provided by the client. This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, LTD.