



# EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 786-5974

<http://www.EMSL.com>

[cinnaminsonleadlab@emsl.com](mailto:cinnaminsonleadlab@emsl.com)

EMSL Order:	201809604
CustomerID:	TTIE54
CustomerPO:	026027
ProjectID:	

Attn: **Mike Stocku**  
**TTI Environmental Inc.**  
**1253 N. Church Street**  
**Moorestown, NJ 08057**

Phone:  
 Fax: (856) 840-8815  
 Received: 08/27/18 9:00 AM  
 Collected: 8/24/2018

Project: **Warren Twp 18-975**

## Test Report: Lead in Water by Furnace AAS (EPA 200.9)

<i>Client Sample Description</i>	<i>Lab ID</i>	<i>Collected</i>	<i>Analyzed</i>	<i>Lead Concentration</i>
29A-W-B-Hall2 Site: Hall by Room 27 - Initial	201809604-0001	8/24/2018	8/31/2018	<3.00 ppb
29B-W-WC-Hall2 Site: Hall by Room 27 - Initial	201809604-0002	8/24/2018	8/31/2018	<3.00 ppb
31A-M-B-LIB Hall Site: By 8th Grade Lounge - Initial	201809604-0003	8/24/2018	8/31/2018	<3.00 ppb
31B-M-WC-LIB Hall Site: By 8th Grade Lounge - Initial	201809604-0004	8/24/2018	8/31/2018	<3.00 ppb
34B-M-WC-Hall A Site: By Teachers Entrance - Initial	201809604-0005	8/24/2018	8/31/2018	<3.00 ppb
34A-M-B-Hall2 Site: By Teachers Entrance - Initial	201809604-0006	8/24/2018	8/31/2018	<3.00 ppb
41-C-WC-APR Site: In APR Room - Initial	201809604-0007	8/24/2018	8/31/2018	<3.00 ppb
40-C-B-APR Site: In APR Room - Initial	201809604-0008	8/24/2018	8/31/2018	<3.00 ppb
36B-MH-HC-HallC Site: C Hall by Boiler Room	201809604-0009	8/24/2018	8/31/2018	<3.00 ppb
36A-MH-B-Hall C Site: C Hall by Boiler Room - Initial	201809604-0010	8/24/2018	8/31/2018	<3.00 ppb
46b-T-WC-Hall A Site: Hallway across from Library - Initial	201809604-0011	8/24/2018	8/31/2018	<3.00 ppb
46a-T-B-Hall A Site: Hallway across from Library - Initial	201809604-0012	8/24/2018	8/31/2018	<3.00 ppb
59-T-WC-Copy Site: Copy Room - Initial	201809604-0013	8/24/2018	8/31/2018	<3.00 ppb
58-T-B-Copy Site: Copy Room - Initial	201809604-0014	8/24/2018	8/31/2018	<3.00 ppb

Phillip Worby, Lead Laboratory Manager  
or other approved signatory

The test results contained within this report meet the requirements of NELAC unless otherwise noted. This report relates only to those items tested. Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted. "<" (less than) result signifies that the analyte was not detected at or above the reporting limit. Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ

Initial report from 09/05/2018 09:31:32