



556 South Mansfield Street
Ypsilanti, MI 48197
1-800-604-1995

Lead Only

Analysis Report

Customer: LEW Corp
1090 Bristol Rd
Mountainside NJ 07092

Report Number: 16-11-03203
Received Date: 11/15/2016
Reported Date: 12/8/2016
Sampled By: Neil Wendt
Tech. Certification #:

P.O. Number: 160857

Project Test/Address: A.L. Tomaso School; 46 Washington; Warren, NJ 07059

Client Number: 201327

Report Notes

Sample #	Sample ID	Method	Parameter	Level Detected	EPA Standard	Units	LRL	Sampled	Analyzed
744162	01-T-S-bath1 Bath1 Mens Rm	200.8	Lead	7	15	ug/L	1	11/10/2016	12/2/2016
744163	02-T-S-bath2 Ladies Rm	200.8	Lead	10	15	ug/L	1	11/10/2016	12/2/2016
744164	03-T-B-Kithall Kitchen Hall	200.8	Lead	4	15	ug/L	1	11/10/2016	12/2/2016
744165	04-T-B-Kithall Kitchen Hall	200.8	Lead	2	15	ug/L	1	11/10/2016	12/2/2016
744166	05-T-S-Kit Kitchen	200.8	Lead	2	15	ug/L	1	11/10/2016	12/2/2016
744167	06-T-S-Kit Kitchen	200.8	Lead	ND	15	ug/L	1	11/10/2016	12/2/2016
744168	08-T-B-Caf Cafeteria	200.8	Lead	1	15	ug/L	1	11/10/2016	12/2/2016
744169	09-T-B-GymHall Gym Hall	200.8	Lead	ND	15	ug/L	1	11/10/2016	12/2/2016
744170	10-T-B-GymHall Gym Hall	200.8	Lead	1	15	ug/L	1	11/10/2016	12/2/2016
744171	11-T-S-Bath3 Bath 3	200.8	Lead	7	15	ug/L	1	11/10/2016	12/2/2016
744172	12-T-S-Bath4 Bath 4	200.8	Lead	3	15	ug/L	1	11/10/2016	12/2/2016
744173	13-T-S-Rm16 Rm 16	200.8	Lead	6	15	ug/L	1	11/10/2016	12/2/2016
744174	14-T-B-Rm16 Rm 16	200.8	Lead	4	15	ug/L	1	11/10/2016	12/2/2016
744175	15-T-SB-Rm16 Rm 16	200.8	Lead	7	15	ug/L	1	11/10/2016	12/2/2016
744176	16-T-B-HallC Hall C	200.8	Lead	6	15	ug/L	1	11/10/2016	12/2/2016
744177	17-T-SB-Rm14 Rm 14	200.8	Lead	15	15	ug/L	1	11/10/2016	12/2/2016
744178	18-T-B-Rm14 Rm 14	200.8	Lead	22	15	ug/L	1	11/10/2016	12/2/2016
744179	19-T-S-Rm14 Rm 14	200.8	Lead	8	15	ug/L	1	11/10/2016	12/2/2016
744180	20-T-SB-Rm13 Rm 13	200.8	Lead	8	15	ug/L	1	11/10/2016	12/2/2016
744181	21-T-S-Rm13 Room 13	200.8	Lead	5	15	ug/L	1	11/10/2016	12/2/2016
744182	22-T-SB-RmK1 Rm K1	200.8	Lead	ND	15	ug/L	1	11/10/2016	12/2/2016
744183	23-T-SB-RmK2 Room K2	200.8	Lead	ND	15	ug/L	1	11/10/2016	12/2/2016
744184	24-T-B-HallC Hall C	200.8	Lead	2	15	ug/L	1	11/10/2016	12/2/2016
744185	25-T-SB-Rm18 Room 18	200.8	Lead	7	15	ug/L	1	11/10/2016	12/2/2016

Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc. were provided by the client. This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, LTD.

Sample #	Sample ID	Method	Parameter	Level Detected	EPA Standard	Units	LRL	Sampled	Analyzed
744186	26-T-SB-Rm20 Room 20	200.8	Lead	6	15	ug/L	1	11/10/2016	12/2/2016
744187	27-T-SB-Rm22 Room22	200.8	Lead	7	15	ug/L	1	11/10/2016	12/2/2016
744188	28-T-S-Rm23 Room 23	200.8	Lead	6	15	ug/L	1	11/10/2016	12/2/2016
744189	29-T-S-Rm24 Room 24	200.8	Lead	5	15	ug/L	1	11/10/2016	12/2/2016
744190	30-T-SB-Rm25 Room 25	200.8	Lead	6	15	ug/L	1	11/10/2016	12/2/2016
744191	31-T-SB-Rm27 Room 27	200.8	Lead	2	15	ug/L	1	11/10/2016	12/2/2016
744192	32-T-SB-Rm29 Room 29	200.8	Lead	2	15	ug/L	1	11/10/2016	12/2/2016
744193	33-T-SB-Rm26 Room 26	200.8	Lead	2	15	ug/L	1	11/10/2016	12/2/2016
744194	34-T-SB-Rm28 Room 28	200.8	Lead	2	15	ug/L	1	11/10/2016	12/2/2016
744195	35-T-SB-Rm33 Room 33	200.8	Lead	ND	15	ug/L	1	11/10/2016	12/2/2016
744196	36-T-S-Bath5 Bath 5	200.8	Lead	1	15	ug/L	1	11/10/2016	12/2/2016
744197	37-T-S-Bath6 Bath 6	200.8	Lead	2	15	ug/L	1	11/10/2016	12/2/2016
744198	38-T-SB-Rm31 Room 31	200.8	Lead	3	15	ug/L	1	11/10/2016	12/2/2016
744199	39-T-SB-Rm30 Room 30	200.8	Lead	3	15	ug/L	1	11/10/2016	12/2/2016
744200	40-T-S-Rm1 Room 1	200.8	Lead	ND	15	ug/L	1	11/10/2016	12/2/2016
744201	41-T-S-Nurse Nurse	200.8	Lead	ND	15	ug/L	1	11/10/2016	12/2/2016
744202	42-T-S-Nurse Nurse	200.8	Lead	2	15	ug/L	1	11/10/2016	12/2/2016
744203	43-T-S-Staff Staff Rm	200.8	Lead	2	15	ug/L	1	11/10/2016	12/2/2016
744204	44-T-S-lib Library	200.8	Lead	8	15	ug/L	1	11/10/2016	12/2/2016
744205	45-T-S-Bath7 Bath 7	200.8	Lead	3	15	ug/L	1	11/10/2016	12/2/2016
744206	46-T-S-HallA Hall A	200.8	Lead	2	15	ug/L	1	11/10/2016	12/2/2016
744207	47-T-S-Bath8 Bath 8	200.8	Lead	3	15	ug/L	1	11/10/2016	12/2/2016
744208	48-T-SB-Rm6 Rm 6	200.8	Lead	30	15	ug/L	1	11/10/2016	12/2/2016
744209	49-T-SB-Rm8 Room 8	3113B	Lead	3	15	ug/L	1	11/10/2016	12/2/2016
744210	50-T-SB-Rm7 Room 7	3113B	Lead	12	15	ug/L	1	11/10/2016	12/2/2016
744211	51-T-SB-Rm9 Room 9	3113B	Lead	8	15	ug/L	1	11/10/2016	12/2/2016
744212	52-T-SB-Rm11 Room 11	3113B	Lead	ND	15	ug/L	1	11/10/2016	12/2/2016
744213	53-T-SB-Rm10 Room 10	3113B	Lead	4	15	ug/L	1	11/10/2016	12/2/2016
744214	54-T-SB-Rm12 Room 12	3113B	Lead	1	15	ug/L	1	11/10/2016	12/2/2016
744215	55-T-SB-RmC Room C	3113B	Lead	ND	15	ug/L	1	11/10/2016	12/2/2016
744216	56-T-SB-RmB Room B	3113B	Lead	ND	15	ug/L	1	11/10/2016	12/2/2016
744217	57-T-SB-RmA Room A	3113B	Lead	10	15	ug/L	1	11/10/2016	12/3/2016
744218	ASTM 58 Blank Tamasso	3113B	Lead	ND	15	ug/L	1	11/10/2016	12/3/2016

Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc. were provided by the client. This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, LTD.

Sample #	Sample ID	Method	Parameter	Level Detected	EPA Standard	Units	LRL	Sampled	Analyzed
----------	-----------	--------	-----------	----------------	--------------	-------	-----	---------	----------

Analyst	Tests
EC, JP	3113B, 200.8

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty for the test results are available upon request. All Dates and Times are reported as Eastern Time.

Legend:

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL).
- "NA" Not analyzed.
- "EPA Standard" This column indicates the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "P/A" Presence/Absence

Reviewed by Authorized Signatory

