



556 South Mansfield Street
Ypsilanti, MI 48197
1-800-604-1995

Lead Only

Analysis Report

Customer: LEW Corp
1090 Bristol Rd
Mountainside NJ 07092

Report Number: 16-11-03212
Received Date: 11/17/2016
Reported Date: 12/1/2016
Sampled By: Neil Wendt
Tech. Certification #:

P.O. Number:

Project Test/Address: Central School; 109 Mt. Bethel Rd., Warren, NJ 07059

Client Number: 201327

Sample #	Sample ID	Method	Parameter	Level Detected	EPA Standard	Units	LRL	Sampled	Analyzed
744264	01-C-B-BH Basement Hall	200.8	Lead	3	15	ug/L	1	11/10/2016	11/23/2016
744265	02-C-5-Bath1 Boys Rm	200.8	Lead	4	15	ug/L	1	11/10/2016	11/23/2016
744266	03-C-5-Bath2 Girls Rm	200.8	Lead	4	15	ug/L	1	11/10/2016	11/23/2016
744267	04-C-5-Art Art Rm	200.8	Lead	ND	15	ug/L	1	11/10/2016	11/23/2016
744268	05-C-5-Kit Kitchen	200.8	Lead	4	15	ug/L	1	11/10/2016	11/23/2016
744269	06-C-5-bath3 Girls Rm	200.8	Lead	2	15	ug/L	1	11/10/2016	11/23/2016
744270	07-C-5-Nurse Nurse	200.8	Lead	2	15	ug/L	1	11/10/2016	11/23/2016
744271	08-C-5-bath4 Nurse	200.8	Lead	1	15	ug/L	1	11/10/2016	11/23/2016
744272	09-C-5-bath5 Nurse	200.8	Lead	1	15	ug/L	1	11/10/2016	11/23/2016
744273	10-C-WC-MainHall Main Hall	200.8	Lead	ND	15	ug/L	1	11/10/2016	11/23/2016
744274	11-C-WC-MainHall Main Hall	200.8	Lead	1	15	ug/L	1	11/10/2016	11/23/2016
744275	12-C-5-Staff Staff Rm	200.8	Lead	ND	15	ug/L	1	11/10/2016	11/23/2016
744276	13-C-5-bath6 Bath6 boys rm	200.8	Lead	1	15	ug/L	1	11/10/2016	11/23/2016
744277	15-C-5-bath7 girls rm	200.8	Lead	1	15	ug/L	1	11/10/2016	11/23/2016
744278	16-C-5-Bath8 boys rm	200.8	Lead	4	15	ug/L	1	11/10/2016	11/23/2016
744279	17-C-WC-HallA Hall A	200.8	Lead	ND	15	ug/L	1	11/10/2016	11/23/2016
744280	20-C-B-HallA Hall A	200.8	Lead	1	15	ug/L	1	11/10/2016	11/23/2016
744281	21-C-5B-Rm16 Room 16	200.8	Lead	12	15	ug/L	1	11/10/2016	11/23/2016
744282	22-C-5B-Rm17 Room 17	200.8	Lead	1	15	ug/L	1	11/10/2016	11/23/2016
744283	23-C-WCA-HallB Hall B	200.8	Lead	ND	15	ug/L	1	11/10/2016	11/23/2016
744284	24-CWCB-HallB Hall B	200.8	Lead	ND	15	ug/L	1	11/10/2016	11/23/2016
744285	25-C-5-bath9 Girls Rm	200.8	Lead	ND	15	ug/L	1	11/10/2016	11/23/2016
744286	26-C-5-bath10 bath 10	200.8	Lead	1	15	ug/L	1	11/10/2016	11/23/2016
744287	27-C-5B-Rm20 Room 20	200.8	Lead	1	15	ug/L	1	11/10/2016	11/23/2016
744288	28-C-5B-Rm21 Room 21	200.8	Lead	7	15	ug/L	1	11/10/2016	11/23/2016
744289	29-C-5B-Rm22 Room 22	200.8	Lead	2	15	ug/L	1	11/10/2016	11/23/2016

Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc. were provided by the client. This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, LTD.

Sample #	Sample ID	Method	Parameter	Level		Units	LRL	Sampled	Analyzed
				Detected	EPA Standard				
744290	30-C-5B-Hall C Hall C	200.8	Lead	2	15	ug/L	1	11/10/2016	11/23/2016
744291	31-C-5B-Rm23 Room 23	200.8	Lead	3	15	ug/L	1	11/10/2016	11/23/2016
744292	32-C-5B-Rm24 Room 24	200.8	Lead	13	15	ug/L	1	11/10/2016	11/23/2016
744293	33-C-WC-HallC Hall C	200.8	Lead	ND	15	ug/L	1	11/10/2016	11/24/2016
744294	38-C-5B-Rm28 Room 28	200.8	Lead	5	15	ug/L	1	11/10/2016	11/24/2016
744295	39-C-5B-Rm27 Room 27	200.8	Lead	3	15	ug/L	1	11/10/2016	11/24/2016
744296	ASTM Blank Central School	200.8	Lead	ND	15	ug/L	1	11/10/2016	11/24/2016

Analyst	Tests
JP	200.8

The results herein conform to TNI and ISO/IEC 17025:2005 standards, where applicable, unless otherwise narrated in the body of the report. The uncertainty for the test results are available upon request. All Dates and Times are reported as Eastern Time.

Report Notes:

Legend:

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL).
- "NA" Not analyzed.
- "EPA Standard" This column indicates the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "P/A" Presence/Absence

Reviewed by Authorized Signatory

