P.O. BOX 4440 CHERRY HILL, NJ 08034 (856) 424-8151 • (877) 878-8111 • FAX (856) 424-9081

March 18, 2019

N J Radon Business License No. MEB 90003

Mr. Michael Pate Supervisor of Buildings and Grounds Warren Township School District 94 Mountain Avenue Warren, NJ 07059

Dear Mr. Pate:

The results of the radon in air tests performed at located at the Middle School located at 100 Old Stirling Road, Warren, NJ are presented in Table 1.

These levels are considered to be in the range where no further action is required based on guidance provided by the U.S. Environmental Protection Agency (EPA). The U.S. Environmental Protection Agency and The Centers for Disease Control have used a continuous exposure level equal to or greater than 4 pCi/L or 0.02 WL as a guidance level at which remedial action is necessary. In some cases the radon level can be lowered with the installation of a radon mitigation system. If you would like to reduce your level further please contact a licensed radon mitigation company.

The enclosed pamphlet from the New Jersey Department of Environmental Protection Radon Program discusses the basic information on radon testing and mitigation.

Since the radon level in your home may change, A&M suggests that you retest every 5 years. Additionally, a retest would also be appropriate following a modification to your home which may cause greater in leakage of radon gas from the soil or reduced removal of gas from the interior of the structure.

The analyses were performed by Accustar Labs, PO Box 562, Jonestown, PA 17038 #PA955.

This notice is provided to you by an organization or individual certified by the New Jersey Department of Environmental Protection to perform radon and/or radon progeny measurement.

N.J.S.A. 26:2D-73 requires that no person disclose to any individual, except the Department of Environmental Protection or the Department of Health the address or owner of a nonpublic building that the person has tested or treated for the presence of radon gas and radon progeny, unless the owner of the building waives, in writing, this right of confidentially. In the case of a prospective sale of a building which has been tested for radon gas and/or radon progeny, the seller shall provide the buyer, at the time the contract of sale in entered into, with a copy of the results of that test and evidence of any subsequent mitigation or treatment, and any prospective buyer who contracts for the testing shall have the right to receive the results of that testing. Any questions, comments, or complaints regarding the persons performing these measurements, related mitigation, or safeguarding services should be directed to the New Jersey Department of Environmental Protection. Attention: Radon Section, Bureau of Environmental Radiation (1-800-648-0394).

Thank you for using our services and in the event that A & M may provide further assistance, please feel free to call.

Very truly yours,

Michael S. Stocknoff, RE. Radon Measurement Specialist

License No. MES 10007

#### Radon in Air Results

Test dates: 3/4/19 - 3/6/19

Test times: 1345 - 1145

Test device: Charcoal Canister

Middle School

100 Old Stirling Road

Location	Results (pCi/L)
Room 35 - Shop	<0.4
Room 35 - Shop Office	<0.4
Room 35- Shop Storage	< 0.4
Finish Room	<0.4
Room 34	<0.4
All Purpose - Left	< 0.4
All Purpose - Right	0.5
Room 33 - Front	< 0.4
Room 33 - Front - Duplicate	<0.4
Room 33 - Rear	< 0.4
Room 4	<0.4
Room 4 - Duplicate	<0.4
Room 4 - Blank	< 0.4
CST	< 0.4
Room 7	<0.4
Room 6	< 0.4

#### Radon in Air Results

Test dates: 3/4/19 - 3/6/19

Test times: 1345 - 1145

Test device: Charcoal Canister

Middle School

100 Old Stirling Road

Location	Results (pCi/L)
Room 9	< 0.4
Room 8	< 0.4
Room 10	< 0.4
Room 11	< 0.4
Room 1	<0.4
Room 1 - Duplicate	0.4
Room 2	< 0.4
Room 2A	< 0.4
Room 2B	< 0.4
Room 2C	< 0.4
Room 3	< 0.4
Room 5	< 0.4
Staff	<0.4
Room 5A	<0.4
Room 8	<0.4
Room 8 - Duplicate	<0.4

#### Radon in Air Results

Test dates: 3/4/19 - 3/6/19

Test times: 1345 - 1145

Test device: Charcoal Canister

Middle School

100 Old Stirling Road

Location	Results (pCi/L)
Room 8 - Blank	< 0.4
Room 6	< 0.4
Ms. Johnson	< 0.4
Ms. Bond	0.4
Conference Room	< 0.4
Ms. Rob	< 0.4
Principal	< 0.4
Main Office	<0.4
Library - Office - Front	<0.4
ibrary - Office - Front - Duplica	<0.4
Library - Office - Rear	<0.4
Media Room	<0.4
Computer Room - Left	<0.4
Computer Room - Right	< 0.4
Room 32	<0.4

#### Radon in Air Results

Test dates: 3/4/19 - 3/6/19

Test times: 1345 - 1145

Test device: Charcoal Canister

Middle School

100 Old Stirling Road

Location	Results (pCi/L)
Nurse	<0.4
Nurse Exterior	< 0.4
Tech Room	<0.4
Room 19	<0.4
Room 19 - Duplicate	< 0.4
Room 19 - Blank	<0.4
Room 18	<0.4
Room 16	<0.4
Room15	< 0.4
Room 14	< 0.4
Room 13	< 0.4
Room 17 - Front	< 0.4
Room 17 - Rear	< 0.4
Room 28	< 0.4
Room 28 - Duplicate	0.4
Room 28 - Blank	<0.4

#### Radon in Air Results

Test dates: 3/4/19 - 3/6/19

Test times: 1345 - 1145

Test device: Charcoal Canister

Middle School

100 Old Stirling Road

Location	Results (pCi/L)
Room 30	< 0.4
Room 27	0.5
Room 29	< 0.4
Home Art	<0.4
Home Art - Office	< 0.4
Library - Left	< 0.4
Library - Right	0.4
Gym 1 - Left	< 0.4
Gym 1 - Right	<0.4
Gym 2 - Front - Right	< 0.4
Gym 2 - Center - Right	< 0.4
Gym 2 - Rear - Right	<0.4
Boys Locker Room	< 0.4
Girls Locker Room	<0.4
Girls Locker Room - Duplicate	0.5

# Table 1 Radon in Air Results

Test dates: 3/4/19 - 3/6/19

Test times: 1345 - 1145

Test device: Charcoal Canister

Middle School

100 Old Stirling Road

Location	Results (pCi/L)
Room 36	< 0.4
Room 36 - Blank	< 0.4
Teacher Planning	<0.4
Teacher Planning - Duplicate	< 0.4
Room 20	< 0.4
Room 21	<0.4
Room 22	<0.4
Room 23	< 0.4
Room 24	<0.4
Room 26	< 0.4
Room 25	<0.4
Room 25A	<0.4
Room 47	<0.4
Room 47 - Duplicate	< 0.4
Room 48	< 0.4
Room 49	< 0.4
Room 50	<0.4

### Radon in Air Results

Test dates: 3/4/19 - 3/6/19

Test times: 1345 - 1145

Test device: Charcoal Canister

Middle School

100 Old Stirling Road

Location	Results (pCi/L)
Room 51	< 0.4
Room 53	< 0.4
Room 52	< 0.4
Faculty	< 0.4
Room 44	0.5
Music - Left	0.5
Music Office	0.6
Custodian	< 0.4
Room 38	< 0.4
Team Planning	< 0.4
Electrical	< 0.4
Room 39	<0.4
Room 41	<0.4
Room 41A	< 0.4
Room 41A - Duplicate	< 0.4
Room 41A - Blank	<0.4

# Table 1 Radon in Air Results

Test dates: 3/4/19 - 3/6/19

Test times: 1345 - 1145

Test device: Charcoal Canister

Middle School

100 Old Stirling Road

Location	Results (pCi/L)
Room 42	< 0.4
Room 43A	< 0.4
Room 43	<0.4
Room 45	0.9
Room 45A	< 0.4
Room 40	<0.4
Room 47A	<0.4
Room 46	< 0.4
Guidance Room	0.6
Room 12	< 0.4